

UUT Report

Station ID: IT-W-7303101  
Serial Number: NONE  
Date: lunedì 6 novembre 2023  
Time: 11:07:09  
Operator: administrator  
Execution Time: 75.457716 seconds  
Number of Results: 60  
UUT Result: Terminated  
Product: MOD LV  
Product type: MOD LV  
Comm type: COMM1\_RS485  
Product FW Version: 56010807  
Comm FW Version: 56010000

Begin Sequence: MainSequence  
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD\_Shared\TestStand\Sequences\MOD\General\_test.seq)

Simultaneous trip_open	
Status:	Skipped
General and Architecture and LED	
Status:	Skipped
Input-Output	
Status:	Terminated
Module Time:	70.8043739

Begin Sequence: I/O  
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD\_Shared\TestStand\Sequences\MOD\General\_test.seq)

Additional Results	
Status:	Done
PopupString:	Check that remote closing hasn't appened.
Status:	Passed
Additional Results	
Status:	Done
PopupString:	Check that remote closing hasn't appened.
Status:	Passed
Additional Results	
Status:	Done
PopupString:	Check that remote opening hasn't appened.
Status:	Passed
Additional Results	
Status:	Done
PopupString:	Check that remote opening hasn't appened.
Status:	Passed
Check Outputs	
Status:	Failed
Configuration:	MOD in Active State and MPD OPEN
Output 1:	True

Output 2:	False
Additional Results	
Status:	Done
PopupString:	Check that remote opening worked.
Status:	Passed

End Sequence: I/O

End Sequence: MainSequence

End UUT Report

