

UUT Report

Station ID: IT-W-7303101
Serial Number: NONE
Date: venerdì 27 ottobre 2023
Time: 11:07:47
Operator: administrator
Execution Time: 465.4249139 seconds
Number of Results: 56
UUT Result: Terminated
Product: MOD LV
Product type: MOD HV
Comm type: COMM1_RS485
Product FW Version: 56010805
Comm FW Version: 56010000

Begin Sequence: MainSequence
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)

Simultaneous trip_open	
Status:	Skipped
General and Architecture and LED	
Status:	Skipped
Input-Output	
Status:	Terminated
Module Time:	461.6947369

Begin Sequence: I/O
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)

Additional Results	
Status:	Done
PopupString:	Check that remote closing hasn't appened.
Status:	Passed
Additional Results	
Status:	Done
PopupString:	Check that remote closing hasn't appened.
Status:	Passed
Additional Results	
Status:	Done
PopupString:	Check that remote opening hasn't appened.
Status:	Passed
Additional Results	
Status:	Done
PopupString:	Check that remote opening hasn't appened.
Status:	Passed
Check Outputs	
Status:	Failed
Configuration:	MOD in Active State and MPD OPEN
Output 1:	True

Output 2:	True
Additional Results	
Status:	Done
PopupString:	Check that remote opening worked.
Status:	Passed
Check Outputs	
Status:	Failed
Configuration:	MOD in Active State and MPD OPEN
Output 1:	True
Output 2:	True
Check Outputs	
Status:	Failed
Configuration:	MOD in Active State and MPD OPEN
Output 1:	True
Output 2:	True

End Sequence: I/O

End Sequence: MainSequence

End UUT Report
