UUT Report

Station ID:	IT-W-7303101
Serial Number:	NONE
Date:	martedì 12 settembre 2023
Time:	12:38:38
Operator:	administrator
Execution Time:	11.4895802 seconds
Number of Results:	94
UUT Result:	**Terminated**
Serial Number:	4294967295
Type Designator:	B3-D4MB-111A
FW Version:	0.18.143
Power Supply:	Production Port

Begin Sequence: MainSequence
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\EQ Meter\New Sequences\D13-Input_State.seq)

Pass/Fail Test	
Status:	Passed
Input Voltage:	0
Input State:	False

Pass/Fail Test	
Status:	Passed
Input Voltage:	0.5
Input State:	False

Pass/Fail Test	
Status:	Passed
Input Voltage:	1
Input State:	False

Pass/Fail Test	
Status:	Passed
Input Voltage:	1.5
Input State:	False

Pass/Fail Test	
Status:	Passed
Input Voltage:	2
Input State:	False

Pass/Fail Test	
Status:	Passed
Input Voltage:	2.5
Input State:	False

Pass/Fail Test	
Status:	Passed
Input Voltage:	3
Input State:	False

Pass/Fail Test	
Status:	Passed
Input Voltage:	3.5
Input State:	False

End Sequence: MainSequence

End UUT Report