UUT Report

Station ID:	IT-W-7303101
Serial Number:	NONE
Date:	mercoledì 8 novembre 2023
Time:	09:43:39
Operator:	administrator
Execution Time:	501.3715991 seconds
Number of Results:	249
UUT Result:	**Terminated**
Product:	ARI-30
Product type:	ARI-30
Comm type:	COMM1_RS485
Product FW Version:	56010807
Comm FW Version:	56010000

Begin Sequence: MainSequence
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)

Double_trip_ARI_blocked	
Status:	Skipped

Simultaneous trip_open	
Status:	Skipped

General and Architecture and LED	
Status:	Skipped

Input-Output	
Status:	Failed
Module Time:	488.0833795

Begin Sequence: I/O
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)

Additional Results	
Status:	Done
PopupString:	Check that remote closing hasn't appened.
Status:	Passed

Additional Results	
Status:	Done
PopupString:	Check that remote closing hasn't appened.
Status:	Passed

Additional Results	
Status:	Done
PopupString:	Check that remote opening hasn't appened.
Status:	Passed

Additional Results	
Status:	Done
PopupString:	Check that remote opening hasn't appened.
Status:	Passed

Check Outputs	
Status:	Passed
Configuration:	MOD in Active State and MPD OPEN
Output 1:	False

Output 2:	True
Additional Results	
Status:	Done
PopupString:	Check that remote opening worked.
Status:	Passed
Check Outputs	
Status:	Passed
Configuration:	MOD in Active State and MPD OPEN
Output 1:	False
Output 2:	False
Check Outputs	
Status:	Passed
Configuration:	MOD in Active State and MPD OPEN
Output 1:	False
Output 2:	False
Check Outputs	
Status:	Passed
Configuration:	MOD in Active State and MPD HALF OPEN
Output 1:	False
Output 2:	True
Check Outputs	
Status:	Passed
Configuration:	MOD in Active State and MPD HALF OPEN
Output 1:	False
Output 2:	True
Additional Results	
Status:	Done
PopupString:	Check that remote closing worked.
Status:	Passed

Check Outputs stand-by	
Status:	Passed
Configuration:	MOD in Lock State
Output 1:	False
Output 2:	True
Additional Results	
Status:	Done
PopupString:	Check that closing has not worked due to input command but for the auto-reclosing.
Status:	Passed
Additional Results	
Status:	Done
PopupString:	Check ARI is in Lock state.
Status:	Passed
Check Outputs	
Status:	Passed
Configuration:	MOD in Lock State
Output 1:	True
Output 2:	False
Check Outputs	
Status:	Failed
Configuration:	MOD in Lock State
Output 1:	True
Output 2:	False

Check Outputs	
Status:	Passed
Configuration:	MOD in Lock State
Output 1:	False
Output 2:	True
Additional Results	
Status:	Done
PopupString:	Check that remote closing not worked.
Status:	Passed

End Sequence: I/O

End Sequence: MainSequence

End UUT Report