

# UUT Report

**Station ID:** IT-W-7303101  
**Serial Number:** NONE  
**Date:** martedì 20 dicembre 2022  
**Time:** 11:48:30  
**Operator:** ITLAVIT1  
**Execution Time:** 00:00:49.754  
**Number of Results:** 335  
**UUT Result:** Passed

---

**Begin Sequence:** MainSequence  
(C:\Users\itlavit1\OneDrive - ABB\LabRnD\_Shared\TestStand\Sequences\Modbus RTU settings.seq)

DUT recap	
Status:	Done
TestResults/Data:	
Serial Number:	"
Type Designator:	B1D3MB111A
FW Version:	0.11.0

Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Address:	1
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	9600
Parity:	Even
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	9600
Parity:	None
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	9600
Parity:	Odd
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	19200
Parity:	Even
Pass/Fail Test	
Status:	Passed

TestResults/Data:	
Baud Rate:	19200
Parity:	None
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	19200
Parity:	Odd
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	38400
Parity:	Even
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	38400
Parity:	None
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	38400
Parity:	Odd
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	57600
Parity:	Even
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	57600
Parity:	None
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	57600
Parity:	Odd
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	115200
Parity:	Even
Pass/Fail Test	
Status:	Passed
TestResults/Data:	
Baud Rate:	115200
Parity:	None
Pass/Fail Test	

Status:	Passed
TestResults/Data:	
Baud Rate:	115200
Parity:	Odd

End Sequence: MainSequence

End UUT Report

