

UUT Report

Station ID: IT-W-7303101  
Serial Number: M086AB1000  
Date: mercoledì 11 gennaio 2023  
Time: 09:37:10  
Operator: ITLAVIT1  
Execution Time: 00:04:44.085  
Number of Results: 58  
UUT Result: Failed  
Failure Chain:

Step	Sequence	Sequence File
<a href="#">Pass/Fail Test Slot 2</a>	PMD-1121	PMD-4540_Reactive.seq
<a href="#">PMD-1121</a>	MainSequence	PMD-4540_Reactive.seq

Begin Sequence: MainSequence  
(C:\Users\itlavit1\OneDrive - ABB\LabRnD\_Shared\TestStand\Sequences\M4M\PMD-4540\_Reactive.seq)

DUT recap	
Status:	Done
TestResults/Data:	
Serial Number:	M086AB1000
Type Designator:	M4M20SEA
FW Version:	P2.6.14.0
PMD-1121	
Status:	Failed
Module Time:	284.757

Begin Sequence: PMD-1121  
(C:\Users\itlavit1\OneDrive - ABB\LabRnD\_Shared\TestStand\Sequences\M4M\PMD-4540\_Reactive.seq)

Pass/Fail Test Slot 2	
Status:	Failed
Pass/Fail Test Slot 3	
Status:	Failed
Pass/Fail Test Slot 4	
Status:	Failed
Additional Results	
Status:	Done
TestResults/Data:	
Import:	0.54
Export:	1.27
Import Delay:	1.1
Export Delay:	1.27

Additional Results	
Status:	Done
TestResults/Data:	
Import:	1.1
Export:	1.27
Import Delay:	1.1
Export Delay:	1.84
Additional Results	
Status:	Done
TestResults/Data:	
Import:	14.84
Export:	0
Import Delay:	14.84
Export Delay:	0
Pass/Fail Test T2 Import	
Status:	Failed
Numeric:	0
Limits:	
Low:	0.008
Comparison Type:	GE(>=)

**End Sequence: PMD-1121**

**End Sequence: MainSequence**

**End UUT Report**

---