

UUT Report

Station ID: IT-W-7303101  
Serial Number: NONE  
Date: lunedì 30 ottobre 2023  
Time: 10:08:28  
Operator: administrator  
Execution Time: 265.4180804 seconds  
Number of Results: 205  
UUT Result: Failed  
Product: MOD LV  
Product type: MOD HV  
Comm type: COMM1\_RS485  
Product FW Version: 56010805  
Comm FW Version: 56010000  
Failure Chain:

| Step          | Sequence     | Sequence File    |
|---------------|--------------|------------------|
| Check Outputs | I/O          | General_test.seq |
| Input-Output  | MainSequence | General_test.seq |



Begin Sequence: MainSequence  
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD\_Shared\TestStand\Sequences\MOD\General\_test.seq)

|                                  |             |
|----------------------------------|-------------|
| Simultaneous trip_open           |             |
| Status:                          | Skipped     |
| General and Architecture and LED |             |
| Status:                          | Skipped     |
| Input-Output                     |             |
| Status:                          | Failed      |
| Module Time:                     | 254.5194234 |

Begin Sequence: I/O  
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD\_Shared\TestStand\Sequences\MOD\General\_test.seq)

|                    |   |
|--------------------|---|
| Additional Results |   |
| Status:            | Done                                      |
| PopupString:       | Check that remote closing hasn't appened. |
| Status:            | Passed                                    |
| Additional Results |   |
| Status:            | Done                                      |
| PopupString:       | Check that remote closing hasn't appened. |
| Status:            | Passed                                    |
| Additional Results |   |
| Status:            | Done                                      |
| PopupString:       | Check that remote opening hasn't appened. |
| Status:            | Passed                                    |
| Additional Results |   |
| Status:            | Done                                      |
| PopupString:       | Check that remote opening hasn't appened. |
| Status:            | Passed                                    |
| Check Outputs      |   |

|                    |                                       |
|--------------------|---------------------------------------|
| Status:            | Passed                                |
| Configuration:     | MOD in Active State and MPD OPEN      |
| Output 1:          | False                                 |
| Output 2:          | True                                  |
| Additional Results |                                       |
| Status:            | Done                                  |
| PopupString:       | Check that remote opening worked.     |
| Status:            | Passed                                |
| Check Outputs      |                                       |
| Status:            | Passed                                |
| Configuration:     | MOD in Active State and MPD OPEN      |
| Output 1:          | False                                 |
| Output 2:          | False                                 |
| Check Outputs      |                                       |
| Status:            | Passed                                |
| Configuration:     | MOD in Active State and MPD OPEN      |
| Output 1:          | False                                 |
| Output 2:          | False                                 |
| Check Outputs      |                                       |
| Status:            | Failed                                |
| Configuration:     | MOD in Active State and MPD HALF OPEN |
| Output 1:          | True                                  |
| Output 2:          | True                                  |
| Check Outputs      |                                       |
| Status:            | Failed                                |
| Configuration:     | MOD in Active State and MPD HALF OPEN |
| Output 1:          | False                                 |
| Output 2:          | True                                  |
| Additional Results |                                       |
| Status:            | Done                                  |
| PopupString:       | Check that remote closing worked.     |
| Status:            | Passed                                |

|                    |   |
|--------------------|---|
| Check MOD Outputs  |   |
| Status:            | Failed  |
| Configuration:     | MOD in Lock State   |
| Output 1:          | True  |
| Output 2:          | False   |
| Check MOD Outputs  |   |
| Status:            | Failed  |
| Configuration:     | MOD in Lock State   |
| Output 1:          | True  |
| Output 2:          | False   |
| Additional Results |   |
| Status:            | Done  |
| PopupString:       | Check that remote closing worked.   |
| Status:            | Passed  |
| Additional Results |   |
| Status:            | Done  |
| PopupString:       | Check that remote closing has not appened due to Dead time of 8 seconds after the trip. |
| Status:            | Passed  |
| Additional Results |   |
| Status:            | Done  |
|                    |   |

|              |  |
|--------------|--|
| PopupString: | Check that remote closing has appened after the Dead time of 8 seconds after the trip. |
| Status:      | Passed   |

End Sequence: I/O

|              |         |
|--------------|---------|
| Power Outage |         |
| Status:      | Skipped |
| Motor Driver |         |
| Status:      | Skipped |

|                       |         |
|-----------------------|---------|
| Modbus Register check |         |
| Status:               | Skipped |
| Modbus settings check |         |
| Status:               | Skipped |
| COMM LED & Button     |         |
| Status:               | Skipped |
| Firmware Upgrade      |         |
| Status:               | Skipped |

End Sequence: MainSequence

End UUT Report

