UUT Report

Station ID:	IT-W-7303101
Serial Number:	NONE
Date:	mercoledì 11 ottobre 2023
Time:	12:44:51
Operator:	administrator
Execution Time:	3935.6197881 seconds
Number of Results:	1197
UUT Result:	**Failed**
Product:	ARI LV
Product type:	ARI LV
Comm type:	COMM1_RS485
Product FW Version:	56010804
Comm FW Version:	56010000
Failure Chain:	

Step	Sequence	Sequence File
Pass/Fail Test	Modbus Register check	General_test.seq
Modbus Register check	MainSequence	General_test.seq

Begin Sequence: MainSequence
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)

General and Architecture and LED	
Status:	Skipped

Input-Output	
Status:	Skipped

Power Outage	
Status:	Skipped

Motor Driver	
Status:	Skipped

Modbus Register check	
Status:	Failed
Module Time:	3924.6613713

Begin Sequence: Modbus Register check
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)

Internal communication failure	
Status:	Done
Register Value:	OK
Additional Results	
Status:	Done
PopupString:	Check that the remote opening via modbus worked.
Status:	Passed
Additional Results	
Status:	Done
PopupString:	Check that the remote closing via modbus worked.

Status:		Passed

Additional Results		
Status:	Done	
PopupString:	Check that the remote closing via modbus has not worked due to closing command but for autoreclosing procedure.	
Status:	Passed	

Additional Results		
Status:	Done	
PopupString:	Check that the remote closing via modbus has not worked.	
Status:	Passed	

input		
Status:	Done	
Register Value:	Disable	

Pass/Fail Test		
Status:	Passed	

Communication		
Status:	Done	
Register Value:	Disable	

Pass/Fail Test		
Status:	Passed	

Additional Results		
Status:	Done	
PopupString:	Check that the remote closing via input has not worked.	
Status:	Passed	

Additional Results		
Status:	Done	
PopupString:	Check that the remote closing via modbus has not worked.	
Status:	Passed	

Additional Results		
Status:	Done	
PopupString:	Check that the remote closing via input has not worked.	
Status:	Passed	

Additional Results		
Status:	Done	
PopupString:	Check that the remote closing via modbus has not worked.	
Status:	Passed	

input		
Status:	Done	
Register Value:	Disable	

Pass/Fail Test		
Status:	Passed	

Communication		
Status:	Done	
Register Value:	Disable	

Pass/Fail Test		
Status:	Passed	

Additional Results		

Status:	Done
PopupString:	Check that the remote opening via input has not worked.
Status:	Passed

Additional Results

Status:	Done
PopupString:	Check that the remote opening via modbus has not worked.
Status:	Passed

Additional Results

Status:	Done
PopupString:	Check that the remote opening via input has not worked.
Status:	Passed

Additional Results

Status:	Done
PopupString:	Check that the remote opening via modbus has not worked.
Status:	Passed

input

Status:	Done
Register Value:	Enable

Pass/Fail Test

Status:	Passed

Additional Results

Status:	Done
PopupString:	Check that the remote closing via modbus has not worked.
Status:	Passed

Additional Results

Status:	Done
PopupString:	Check that the remote closing via input worked.
Status:	Passed

Additional Results

Status:	Done
PopupString:	Check that the remote opening via modbus has not worked.
Status:	Passed

Additional Results

Status:	Done
PopupString:	Check that the remote opening via input worked.
Status:	Passed

Communication

Status:	Done
Register Value:	Enable

Pass/Fail Test

Status:	Passed

Additional Results

Status:	Done
PopupString:	Check that the remote closing and opening via input worked.
Status:	Passed

Additional Results

Status:	Done
PopupString:	Check that the remote closing and opening via modbus worked.
Status:	Passed

Additional Results	
Status:	Done
PopupString:	Check that the remote closing via input has not worked.
Status:	Passed

Additional Results	
Status:	Done
PopupString:	Check that the remote closing via modbus worked.
Status:	Passed

Additional Results	
Status:	Done
PopupString:	Check that the remote opening via input has not worked.
Status:	Passed

Additional Results	
Status:	Done
PopupString:	Check that the remote opening via modbus worked.
Status:	Passed

Reclosing attempts	
Status:	Done
Register Value:	3

Waiting time among reclosing	
Status:	Done
Register Value:	3

Neutralization time	
Status:	Done
Register Value:	12

Additional Results	
Status:	Done
PopupString:	Check that the ARI entered the Lock state with the prefixed settings.
Status:	Passed

Reclosing attempts	
Status:	Done
Register Value:	5

Test Update Reclosing attempts	
Status:	Passed

Waiting time among reclosing	
Status:	Done
Register Value:	5

Test Update Time among reclosing	
Status:	Passed

Neutralization time	
Status:	Done
Register Value:	45

Test Update Neutralization time	
Status:	Passed

Additional Results	
Status:	Done

PopupString:	Check that the ARI entered the Lock state with the new settings.
Status:	Passed

Additional Results

Status:	Done
PopupString:	Check that the ARI entered the Lock state with the new settings.
Status:	Passed

Additional Results

Status:	Done
PopupString:	Check with modbus poll that the maximum settable value of the neutralization time and waiting time before reclosing is 300 and the maximum number of reclosing attempts is 10.
Status:	Passed

Status Breaker

Status:	Done
Register Value:	Open

Test Status Breaker

Status:	Passed

Status Breaker

Status:	Done
Register Value:	Open

Test Status Breaker

Status:	Passed

Status Breaker

Status:	Done
Register Value:	Close

Test Status Breaker

Status:	Passed

Status Breaker

Status:	Done
Register Value:	Close

Test Status Breaker

Status:	Passed

Status Breaker

Status:	Done
Register Value:	Open

Test Status Breaker

Status:	Passed

Status Breaker

Status:	Done
Register Value:	Open

Test Status Breaker

Status:	Passed

Tripped

Status:	Done
Register Value:	No Trip

Test Tripped

Status:	Passed

Tripped	
Status:	Done
Register Value:	Trip
Test Tripped	
Status:	Passed
Tripped	
Status:	Done
Register Value:	Trip
Test Tripped	
Status:	Passed
Tripped	
Status:	Done
Register Value:	Trip
Test Tripped	
Status:	Passed

Tripped	
Status:	Done
Register Value:	No Trip
Test Tripped	
Status:	Passed

TIME Tripped	
Status:	Done
Time Tripped before:	000101000000
TIME Tripped	
Status:	Done
Time Tripped after:	000101004042
Time tripped check	
Status:	Passed

| Maneuvre parameters graphs	
Status:	Done
Peak current in mA[0..9]:	
Motor torque in mN-m[0..9]:	

Time to max torque in ms[0..9]:


Peak torque toggle angle in degree[0..9]:

Closing time in ms[0..9]:

Opening time in ms[0..9]:

Maneuver attempt ongoing	
Status:	Done
Register Value:	No Maneuver

Test Maneuvre ongoing	
Status:	Passed

Parallel Call - Read loop	
Status:	Done
Module Time:	0.0026613

Meneuvre Ongoing test	
Status:	Passed

Maneuvre Ongoing Results	
Status:	Done
Value of the register before the first change:	No Maneuver
Value of the register after the first change:	Maneuver ongoing
Number of changes:	2

Maneuver attempt ongoing	
Status:	Done
Register Value:	No Maneuver

Test Maneuvre ongoing	
Status:	Passed

Parallel Call - Read loop	
Status:	Done
Module Time:	0.0017215

Meneuvre Ongoing test	

Status:	Passed
Maneuvre Ongoing Results	
Status:	Done
Value of the register before the first change:	No Maneuver
Value of the register after the first change:	Maneuver ongoing
Number of changes:	2
Maneuver attempt ongoing	
Status:	Done
Register Value:	No Maneuver
Test Maneuvre ongoing	
Status:	Passed
Total Number of maneuvre	
Status:	Done
Register Value:	505
Total Number of closing maneuvre	
Status:	Done
Register Value:	352
Total Number of maneuver	
Status:	Done
Register Value:	525
Test total number maneuvre	
Status:	Passed
Total Number of closing maneuver	
Status:	Done
Register Value:	362
Test total number closing	
Status:	Passed

Total Number of maneuvre	
Status:	Done
Register Value:	525
Total Number of closing maneuvre	
Status:	Done
Register Value:	362
Total Number of maneuver	
Status:	Done
Register Value:	535
Test total number maneuvre	
Status:	Passed
Measurement:	535
Limits:	
Low:	535
Comparison Type:	EQ (==)
Total Number of closing maneuver	
Status:	Done
Register Value:	372
Test total number closing	
Status:	Passed
Measurement:	372
Limits:	

Low:	372
Comparison Type:	EQ (==)

Output 1	
Status:	Done
Register Value:	MOD lever open

Test Output1	
Status:	Passed

Output 2	
Status:	Done
Register Value:	Lock-out state not-active

Test output 2	
Status:	Passed

Input 1	
Status:	Done
Register Value:	Not Active

Test Input 1	
Status:	Passed

Input 2	
Status:	Done
Register Value:	Not Active

Test Input 2	
Status:	Passed

Output 1	
Status:	Done
Register Value:	MOD lever close

Test Output1	
Status:	Passed

Output 2	
Status:	Done
Register Value:	Lock-out state not-active

Test output 2	
Status:	Passed

Input 1	
Status:	Done
Register Value:	Active

Test Input 1	
Status:	Passed

Input 2	
Status:	Done
Register Value:	Not Active

Test Input 2	
Status:	Passed

Output 1	
Status:	Done
Register Value:	MOD lever open

Test Output1	
Status:	Passed

Output 2	

Status:	Done
Register Value:	Lock-out state not-active
Test output 2	
Status:	Passed
Input 1	
Status:	Done
Register Value:	Not Active
Test Input 1	
Status:	Passed
Input 2	
Status:	Done
Register Value:	Active
Test Input 2	
Status:	Passed
Output 1	
Status:	Done
Register Value:	MOD lever open
Test Output1	
Status:	Passed
Output 2	
Status:	Done
Register Value:	Lock-out state not-active

Test output 2	
Status:	Passed

Input 1	
Status:	Done
Register Value:	Not Active
Test Input 1	
Status:	Passed
Input 2	
Status:	Done
Register Value:	Not Active
Test Input 2	
Status:	Passed

Output 1	
Status:	Done
Register Value:	MOD lever open
Test Output1	
Status:	Passed
Output 2	
Status:	Done
Register Value:	Lock state
Test output 2	
Status:	Passed
Input 1	
Status:	Done
Register Value:	Not Active

Test Input 1	
Status:	Passed

Input 2	
Status:	Done
Register Value:	Not Active

Test Input 2	
Status:	Passed

Output 1	
Status:	Done
Register Value:	MOD lever close

Test Output1	
Status:	Passed

Output 2	
Status:	Done
Register Value:	Lock-out state not-active

Test output 2	
Status:	Passed

Input 1	
Status:	Done
Register Value:	Not Active

Test Input 1	
Status:	Passed

Input 2	
Status:	Done
Register Value:	Not Active

Test Input 2	
Status:	Passed

TIME Power Fail	
Status:	Done
Time Power Fail before:	000101000046

TIME Power Fail	
Status:	Done
Time Power Fail after:	000101004830

Time power fail	
Status:	Passed

LAST DEMANDED COMMAND FAILED PF	
Status:	Done
Register Value:	All command completed

Test last demanded command	
Status:	Passed

LAST DEMANDED COMMAND FAILED PF	
Status:	Done
Register Value:	All command completed

Test last demanded command	
Status:	Passed

Parallel Call - Read loop power fail	

Status:	Done
Module Time:	0.0020957
Meneuvre power fail test	
Status:	Passed
Parallel Call - Read loop power fail	
Status:	Done
Module Time:	0.0021753
Meneuvre power fail test	
Status:	Passed
Meneuvre power fail test	
Status:	Passed
Parallel Call - Read loop power fail	
Status:	Done
Module Time:	0.0019572
Meneuvre power fail test	
Status:	Passed

Diagnostic register	
Status:	Done
Register Value:	1
Pass/Fail Test	
Status:	Failed
Diagnostic register	
Status:	Done
Register Value:	1
Pass/Fail Test	
Status:	Passed

Diagnostic register	
Status:	Done
Register Value:	2
Pass/Fail Test	
Status:	Passed
Diagnostic register	
Status:	Done
Register Value:	8
Pass/Fail Test	
Status:	Passed
Diagnostic register	
Status:	Done
Register Value:	4
Pass/Fail Test	
Status:	Passed

Product type number ID MOD	
Status:	Done
Register Value:	ARI LOW VOLTAGE
Product type number ID COMM	
Status:	Done
Register Value:	COMM1_RS485

Product Type MOD	
Status:	Done
Product Type MOD:	ARI_LVÿÿÿÿÿÿÿÿÿÿ

Product Type COMM	
Status:	Done
Product Type COMM:	COMM1_RS485

Serial Number MOD	
Status:	Done
Serial Number MOD:	ÿÿÿÿÿ

Serial Number COMM	
Status:	Done
Serial Number COMM:	ÿÿÿÿÿ

FW Version MOD	
Status:	Done
FW Version MOD:	V☐

FW Version COMM	
Status:	Done
FW Version COMM:	V☐

Modbus RTU parameter Slave Address	
Status:	Done
Register Value:	1

Modbus RTU parameter Baud Rate	
Status:	Done
Register Value:	19200

Modbus RTU parameter Parity	
Status:	Done
Register Value:	EVEN

End Sequence: Modbus Register check

Modbus settings check	
Status:	Skipped

COMM LED & Button	
Status:	Skipped

Firmware Upgrade	
Status:	Skipped

End Sequence: MainSequence

End UUT Report