UUT Report

Station ID:	IT-W-7303101
Serial Number:	NONE
Date:	giovedì 19 ottobre 2023
Time:	09:39:33
Operator:	administrator
Execution Time:	106.4322723 seconds
Number of Results:	88
UUT Result:	**Terminated**
Product:	MOD LV
Product type:	MOD LV
Comm type:	COMM1_RS485
Product FW Version:	56010804
Comm FW Version:	56010000

Begin Sequence: MainSequence
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\FMEA.seq)

Initial state closed	
Status:	Passed
Module Time:	14.8994247

Begin Sequence: Initial State closed
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\FMEA.seq)

Open - Closed - Active - ON - LOG	
Status:	Done
Switch 1:	False
Swtich 2:	True

Comm Close LOG	
Status:	Done

Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Swtich 2:	False

Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Swtich 2:	False

Read Outputs LOG	
Status:	Done
Output_1_SIG:	True
Output_2_AUX:	False

Additional Results	
Status:	Done
Configuration:	How is the status of LED?
Fix_Green:	FIX GREEN

Additional Results	
Status:	Done
Configuration:	How is the status of MDP?
Status:	UNLOCKED

Additional Results	
Status:	Done
Configuration:	Additional notes
Status:	''

End Sequence: Initial State closed

Close command and Switch1 closed - Switch2 open - before command	
Status:	Passed
Module Time:	34.1793675

Begin Sequence: Close command and Switch1 closed - Switch2 open - before command (C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\FMEA.seq)

Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Swtich 2:	False
Comm Close LOG	
Status:	Done
Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Swtich 2:	False
Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Swtich 2:	False
Read Outputs LOG	
Status:	Done
Output_1_SIG:	True
Output_2_AUX:	False

Additional Results	
Status:	Done
Configuration:	How is the status of LED?
Fix_Green:	FIX GREEN
Additional Results	
Status:	Done
Configuration:	How is the status of MDP?
Status:	UNLOCKED

Additional Results	
Status:	Done
Configuration:	Additional notes
Status:	Opening maneuvre fail

End Sequence: Close command and Switch1 closed - Switch2 open - before command

Open command and Switch1 open - Switch2 closed - before command	
Status:	Passed
Module Time:	40.1141138

Begin Sequence: Open command and Switch1 open - Switch2 closed - before command (C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\FMEA.seq)

Open - Closed - Active - ON - LOG	
Status:	Done
Switch 1:	False
Swtich 2:	True

Comm Open LOG	
Status:	Done

Open - Closed - Active - ON - LOG	
Status:	Done
Switch 1:	False
Swtich 2:	True

Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Swtich 2:	False

Read Outputs LOG	
Status:	Done
Output_1_SIG:	True
Output_2_AUX:	False

Additional Results	
Status:	Done
Configuration:	How is the status of LED?
Fix_Green:	FIX GREEN

Additional Results	
Status:	Done
Configuration:	How is the status of MDP?
Status:	UNLOCKED

Additional Results	
Status:	Done
Configuration:	Additional notes
Status:	Closing maneuvre fail

End Sequence: Open command and Switch1 open - Switch2 closed - before command

End Sequence: MainSequence

End UUT Report