UUT Report

Station ID:	IT-W-7303101
Serial Number:	NONE
Date:	lunedì 16 ottobre 2023
Time:	11:52:04
Operator:	administrator
Execution Time:	31.3796117 seconds
Number of Results:	50
UUT Result:	Terminated
Product:	ARI LV
Product type:	ARI LV
Comm type:	COMM1_RS485
Product FW Version:	56010804
Comm FW Version:	56010000

Begin Sequence: MainSequence
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\FMEA.seq)

Check Outputs	
Status:	Failed
Configuration:	MOD in Active State and MPD OPEN
Output 1:	True
Output 2:	False

Additional Results	
Status:	Done
Configuration:	How is the status of LED?
Fix_Green:	FIX GREEN

Additional Results	
Status:	Done
Configuration:	How is the status of LED?
locked_MDP:	LOCKED

Check Outputs	
Status:	Passed
Configuration:	MOD in Active State and MPD OPEN
Output 1:	False
Output 2:	False

End Sequence: MainSequence

End UUT Report