

# UUT Report

**Station ID:** IT-W-7303101  
**Serial Number:** NONE  
**Date:** giovedì 12 gennaio 2023  
**Time:** 14:05:43  
**Operator:** ITLAVIT1  
**Execution Time:** 00:07:48.011  
**Number of Results:** 391  
**UUT Result:** Passed

---

**Begin Sequence: MainSequence**  
(C:\Users\itlavit1\OneDrive - ABB\LabRnD\_Shared\TestStand\Sequences\M4M\PMD-1029.seq)

DUT recap	
Status:	Done
TestResults/Data:	
Serial Number:	L103AB101D
Type Designator:	M4M30SEA
FW Version:	P2.6.14.0
PMD-1029	
Status:	Passed
Module Time:	467.284

**Begin Sequence: PMD-1029**  
(C:\Users\itlavit1\OneDrive - ABB\LabRnD\_Shared\TestStand\Sequences\M4M\PMD-1029.seq)

Touch - Read Timers	
Status:	Passed
Module Time:	80.8717

**Begin Sequence: Touch\_ReadTimers**  
(C:\Users\itlavit1\OneDrive - ABB\LabRnD\_Shared\TestStand\Sequences\M4M\PMD-1029.seq)

Touch - Go Home	
Status:	Passed
Module Time:	26.3348

**Begin Sequence: Touch\_GoHome**  
(C:\Users\itlavit1\OneDrive - ABB\LabRnD\_Shared\TestStand\Sequences\M4M\CommonUtilitySequences.seq)

Pass/Fail - Home Reached	
Status:	Passed

### End Sequence: Touch\_GoHome

Touch - Go To Timers	
Status:	Passed
Module Time:	8.6943
Touch - Go Home	
Status:	Passed
Module Time:	26.484

### Begin Sequence: Touch\_GoHome

(C:\Users\itlavit1\OneDrive -

ABB\LabRnD\_Shared\TestStand\Sequences\M4M\CommonUtilitySequences.seq)

Pass/Fail - Home Reached	
Status:	Passed

### End Sequence: Touch\_GoHome

### End Sequence: Touch\_ReadTimers

Counter Values	
Status:	Done
TestResults/Data:	
Counter UP:	149
Counter DOWN:	112
Counter Up HMI:	149
Counter Down HMI:	111
Wait 2 Minutes	
Status:	Passed
Module Time:	120.235

Touch - Read Timers - After	
Status:	Passed
Module Time:	80.7345

### Begin Sequence: Touch\_ReadTimers

(C:\Users\itlavit1\OneDrive -

ABB\LabRnD\_Shared\TestStand\Sequences\M4M\PMD-1029.seq)

Touch - Go Home	
Status:	Passed
Module Time:	26.6409

**Begin Sequence: Touch\_GoHome**  
**(C:\Users\itlavit1\OneDrive -**  
**ABB\LabRnD\_Shared\TestStand\Sequences\M4M\CommonUtilitySequences.seq)**

Pass/Fail - Home Reached	
Status:	Passed

**End Sequence: Touch\_GoHome**

Touch - Go To Timers	
Status:	Passed
Module Time:	8.65437
Touch - Go Home	
Status:	Passed
Module Time:	26.3163

**Begin Sequence: Touch\_GoHome**  
**(C:\Users\itlavit1\OneDrive -**  
**ABB\LabRnD\_Shared\TestStand\Sequences\M4M\CommonUtilitySequences.seq)**

Pass/Fail - Home Reached	
Status:	Passed

**End Sequence: Touch\_GoHome**

**End Sequence: Touch\_ReadTimers**

Counter Values after 2 Minutes	
Status:	Done
TestResults/Data:	
Counter UP after 2 minute:	152
Counter DOWN after 2 minute:	108
Counter UP HMI after 2 minute:	153
Counter DOWN HMI after 2 minute:	108
COMM - Check Counters After 2 Minutes	
Status:	Passed

Touch - Start Count Down Start	
Status:	Passed
Module Time:	93.5114

**Begin Sequence: Touch\_SetCountDownStart**  
**(C:\Users\itlavit1\OneDrive -**  
**ABB\LabRnD\_Shared\TestStand\Sequences\M4M\PMD-1029.seq)**

Touch - Go Home
-----------------

Status:	Passed
Module Time:	26.3

**Begin Sequence: Touch\_GoHome**  
**(C:\Users\itlavit1\OneDrive -**  
**ABB\LabRnD\_Shared\TestStand\Sequences\M4M\CommonUtilitySequences.seq)**

Pass/Fail - Home Reached	
Status:	Passed

**End Sequence: Touch\_GoHome**

Touch - Go To Count Down Timer	
Status:	Passed
Module Time:	12.9894

**End Sequence: Touch\_SetCountDownStart**

Touch - Read Timers - Reset	
Status:	Passed
Module Time:	80.4442

**Begin Sequence: Touch\_ReadTimers**  
**(C:\Users\itlavit1\OneDrive -**  
**ABB\LabRnD\_Shared\TestStand\Sequences\M4M\PMD-1029.seq)**

Touch - Go Home	
Status:	Passed
Module Time:	26.2775

**Begin Sequence: Touch\_GoHome**  
**(C:\Users\itlavit1\OneDrive -**  
**ABB\LabRnD\_Shared\TestStand\Sequences\M4M\CommonUtilitySequences.seq)**

Pass/Fail - Home Reached	
Status:	Passed

**End Sequence: Touch\_GoHome**

Touch - Go To Timers	
Status:	Passed
Module Time:	8.67427
Touch - Go Home	
Status:	Passed
Module Time:	26.3032

**Begin Sequence: Touch\_GoHome**  
(C:\Users\itlavit1\OneDrive -  
ABB\LabRnD\_Shared\TestStand\Sequences\M4M\CommonUtilitySequences.seq)

Pass/Fail - Home Reached	
Status:	Passed

**End Sequence: Touch\_GoHome**

**End Sequence: Touch\_ReadTimers**

Counter Values after Reset	
Status:	Done
TestResults/Data:	
Counter UP after Reset:	0
Counter DOWN after Reset:	239
Counter UP after Reset HMI:	0
Counter DOWN after Reset HMI:	239
COMM - UP CNT = 0	
Status:	Passed
COMM - DOWN CNT = 240	
Status:	Passed
Numeric:	239
Limits:	
Low:	239
High:	240
Comparison Type:	GELE(>= <=)
HMI - UP CNT = 0	
Status:	Passed
HMI - DOWN CNT = 240	
Status:	Passed
Numeric:	239
Limits:	
Low:	238
High:	240
Comparison Type:	GELE(>= <=)

**End Sequence: PMD-1029**

**End Sequence: MainSequence**

**End UUT Report**

---