

UUT Report

Station ID:

Serial Number:

Date:

Time:

Operator:

Execution Time:

Number of Results:

UUT Result:

Product:

Product type:

Comm type:

Product FW Version:

Comm FW Version:

IT-W-7303101

NONE

martedì 7 novembre 2023

12:07:56

administrator

78.2449104 seconds

49

Terminated

MOD HV

MOD HV

COMM1_RS485

56010807

56010000

Begin Sequence: MainSequence

(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)

| | |
|----------------------------------|---------|
| Double_trip_ARI_blocked | |
| Status: | Skipped |
| Simultaneous trip_open | |
| Status: | Skipped |
| General and Architecture and LED | |
| Status: | Skipped |
| Input-Output | |
| Status: | Skipped |
| Power Outage | |
| Status: | Skipped |
| Motor Driver | |
| Status: | Skipped |

| | |
|-----------------------|------------|
| Modbus Register check | |
| Status: | Terminated |
| Module Time: | 66.1281611 |

Begin Sequence: Modbus Register check

(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)

| | |
|--------------------------------|--|
| Internal communication failure | |
| Status: | Done |
| Register Value: | OK |
| Additional Results | |
| Status: | Done |
| PopupString: | Check that the remote opening via modbus worked. |
| Status: | Passed |
| Additional Results | |
| Status: | Done |
| PopupString: | Check that the remote closing via modbus worked. |
| Status: | Passed |

| | |
|--------------------|---|
| Additional Results | |
| Status: | Done |
| PopupString: | Check that the remote closing via modbus has not worked during dead time. |
| Status: | Passed |
| | |
| Popup PassFail | |
| Status: | Failed |
| | |
| Additional Results | |
| Status: | Done |
| PopupString: | Check that the remote closing via modbus worked. |
| Status: | Failed |

End Sequence: Modbus Register check

End Sequence: MainSequence

End UUT Report
