UUT Report

Station ID:	IT-W-7303101
Serial Number:	NONE
Date:	lunedì 13 novembre 2023
Time:	12:40:44
Operator:	administrator
Execution Time:	855.1349217 seconds
Number of Results:	364
UUT Result:	**Passed**
Product:	MOD LV
Product type:	MOD HV
Comm type:	COMM1_RS485
Product FW Version:	56010809
Comm FW Version:	56010000

Begin Sequence: MainSequence
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)

Double_trip_ARI_blocked	
Status:	Skipped

Simultaneous trip_open	
Status:	Skipped

General and Architecture and LED	
Status:	Passed
Module Time:	225.727949

Begin Sequence: General and Architecture and LED
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)

Additional Results	
Status:	Done
PopupString:	Check that manual opening and closing of the device shall be possible when the device is power off and the LED is OFF.
Status:	Passed

Additional Results	
Status:	Done
PopupString:	Check that manual opening and closing of the device shall be possible when the device is power ON and in NOT-Active state.
Status:	Passed

Additional Results	
Status:	Done
PopupString:	Check that the LED is "Blinking Green" in both active and close configurations.
Status:	Passed

Additional Results	
Status:	Done
PopupString:	Check that the LED is "Blinking Green".
Status:	Passed

Additional Results	
Status:	Done
PopupString:	Check that manual opening and closing of the device shall be possible when the device is power ON and in NOT-Active state.

Status:	Passed

Additional Results	
Status:	Done
PopupString:	Check that the LED is "Blinking Green"in both active and close configurations.
Status:	Passed

Additional Results	
Status:	Done
PopupString:	Check that the LED is "Blinking Green".
Status:	Passed

Additional Results	
Status:	Done
PopupString:	Check that the LED is "Blinking Green"in both active and close configurations.
Status:	Passed

Additional Results	
Status:	Done
PopupString:	Check that manual opening and closing of the device shall be possible when the device is power ON and in Active state.
Status:	Passed

Additional Results	
Status:	Done
PopupString:	Check that the LED is "Fix Green"in both active and close configurations.
Status:	Passed

Additional Results	
Status:	Done
PopupString:	Check that the LED is "Fix Green".
Status:	Passed

Additional Results	
Status:	Done
PopupString:	Check that manual opening and closing of the device shall be possible when the device is power ON and in Active state.
Status:	Passed

Additional Results	
Status:	Done
PopupString:	Check that the LED is "Fix Green"in both active and close configurations.
Status:	Passed

Additional Results	
Status:	Done
PopupString:	Check that the LED is "Fix Green".
Status:	Passed

Additional Results	
Status:	Done
PopupString:	Check that manual opening and closing of the device shall be possible when the device is power ON and in Active state.
Status:	Passed

Additional Results	
Status:	Done
PopupString:	Check that the LED is "Fix Green"in both active and close configurations.
Status:	Passed

Additional Results	
Status:	Done

PopupString:	Check that the LED is "Fix Red".
Status:	Passed

Additional Results	
Status:	Done
PopupString:	Check that manual opening and closing of the device shall be possible when the device is power ON and in Locked state.
Status:	Passed

Additional Results	
Status:	Done
PopupString:	Check that the LED is "Fix Green".
Status:	Passed

Additional Results	
Status:	Done
PopupString:	Check that the LED is "Fix Red".
Status:	Passed

Additional Results	
Status:	Done
PopupString:	Check that manual opening and closing of the device shall be possible when the device is power ON and in Locked state.
Status:	Passed

End Sequence: General and Architecture and LED

Input-Output	
Status:	Passed
Module Time:	222.6614815

Begin Sequence: I/O
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)

Additional Results	
Status:	Done
PopupString:	Check that remote closing hasn't appened.
Status:	Passed

Additional Results	
Status:	Done
PopupString:	Check that remote closing hasn't appened.
Status:	Passed

Additional Results	
Status:	Done
PopupString:	Check that remote opening hasn't appened.
Status:	Passed

Additional Results	
Status:	Done
PopupString:	Check that remote opening hasn't appened.
Status:	Passed

Check Outputs	
Status:	Passed
Configuration:	MOD in Active State and MPD OPEN
Output 1:	False
Output 2:	True

Additional Results	
Status:	Done

PopupString:	Check that remote opening worked.
Status:	Passed

Check Outputs
Status:	Passed
Configuration:	MOD in Active State and MPD OPEN
Output 1:	False
Output 2:	False

Check Outputs
Status:	Passed
Configuration:	MOD in Active State and MPD OPEN
Output 1:	False
Output 2:	False

Check Outputs
Status:	Passed
Configuration:	MOD in Active State and MPD HALF OPEN
Output 1:	False
Output 2:	True

Check Outputs
Status:	Passed
Configuration:	MOD in Active State and MPD HALF OPEN
Output 1:	False
Output 2:	True

Additional Results
Status:	Done
PopupString:	Check that remote closing worked.
Status:	Passed

Check MOD Outputs
Status:	Passed
Configuration:	MOD in Lock State
Output 1:	True
Output 2:	False

Check MOD Outputs
Status:	Passed
Configuration:	MOD in Lock State
Output 1:	True
Output 2:	False

Additional Results
Status:	Done
PopupString:	Check that remote closing worked.
Status:	Passed

Additional Results
Status:	Done
PopupString:	Check that remote closing has not appened due to Dead time of 8 seconds after the trip.
Status:	Passed

Additional Results
Status:	Done
PopupString:	Check that remote closing has appened after the Dead time of 8 seconds after the trip.
Status:	Passed

End Sequence: I/O

Power Outage	
Status:	Passed
Module Time:	362.9069852

Begin Sequence: Power Outage
(C:\Users\itlavit1\OneDrive – ABB\LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)

Additional Results	
Status:	Done
PopupString:	Check that the MOD open automatically the MPD at power On without reclosing.
Status:	Passed
Additional Results	
Status:	Skipped

End Sequence: Power Outage

Motor Driver	
Status:	Skipped

Modbus Register check	
Status:	Skipped
Modbus settings check	
Status:	Skipped
COMM LED & Button	
Status:	Skipped
Firmware Upgrade	
Status:	Skipped

End Sequence: MainSequence

End UUT Report