

UUT Report

Station ID: IT-W-7303101  
Serial Number: NONE  
Date: martedì 21 novembre 2023  
Time: 16:55:47  
Operator: administrator  
Execution Time: 69.3016138 seconds  
Number of Results: 119  
UUT Result: Terminated  
Product: MOD LV  
Product type: MOD LV  
Comm type: COMM1\_RS485  
Product FW Version: 56010809  
Comm FW Version: 56010000

Begin Sequence: MainSequence  
(C:\Users\itlavit1\OneDrive - ABB\LabRnD\_Shared\TestStand\Sequences\MOD\FMEA.seq)

Close command and Switch1 closed - Switch2 open - before command	
Status:	Skipped
Open command and Switch1 open - Switch2 closed - before command	
Status:	Skipped
Close command and switches open - during command	
Status:	Skipped
Close command and switches closed - during command	
Status:	Skipped
Open command and switches closed	
Status:	Skipped
Open command and switches open	
Status:	Skipped
TRIP true	
Status:	Skipped

Initial state closed	
Status:	Skipped

TRIP both switches open	
Status:	Failed
Module Time:	25.2702039

Begin Sequence: TRIP both switches open  
(C:\Users\itlavit1\OneDrive - ABB\LabRnD\_Shared\TestStand\Sequences\MOD\FMEA.seq)

Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Switch 2:	False
Enable Outputs LOG	
Status:	Done
Open - Open - Active - ON - LOG	
Status:	Done
Switch 1:	False

Switch 2:	False
Disable Outputs LOG	
Status:	Done
Open - Closed - Active - ON - LOG	
Status:	Done
Switch 1:	False
Switch 2:	True
Check Outputs	
Status:	Failed
Configuration:	TRIP both switches open
Output_1_SIG:	True
Output_2_AUX:	False

Additional Results	
Status:	Done
Configuration:	How is the status of LED?
Fix_Red:	FIX RED
Additional Results	
Status:	Done
Configuration:	How is the status of MDP?
Status:	UNLOCKED

Additional Results	
Status:	Done
Configuration:	Additional notes
Status:	"

End Sequence: TRIP both switches open

Initial state closed	
Status:	Skipped

TRIP both switches closed	
Status:	Passed
Module Time:	17.4019716

Begin Sequence: TRIP both switches closed  
(C:\Users\itlavit1\OneDrive - ABB\LabRnD\_Shared\TestStand\Sequences\MOD\FMEA.seq)

Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Switch 2:	False
Enable Outputs LOG	
Status:	Done
Closed - Closed - Active - ON - LOG	
Status:	Done
Switch 1:	True
Switch 2:	True
Disable Outputs LOG	
Status:	Done
Open - Closed - Active - ON - LOG	
Status:	Done

Switch 1:	False
Switch 2:	True
Check Outputs	
Status:	Passed
Configuration:	TRIP true
Output_1_SIG:	False
Output_2_AUX:	False

Additional Results	
Status:	Done
Configuration:	How is the status of LED?
Fix_Green:	FIX GREEN

Additional Results	
Status:	Done
Configuration:	How is the status of MDP?
Status:	UNLOCKED

Additional Results	
Status:	Done
Configuration:	Additional notes
Status:	"

End Sequence: TRIP both switches closed

Initial state closed	
Status:	Skipped

TRIP - Switch1 open - Switch2 closed	
Status:	Terminated
Module Time:	17.4014901

Begin Sequence: TRIP - Switch1 open - Switch2 closed  
(C:\Users\itlav1\OneDrive - ABB\LabRnD\_Shared\TestStand\Sequences\MOD\FMEA.seq)

Closed - Open - Active - ON - LOG	
Status:	Done
Switch 1:	True
Switch 2:	False
Enable Outputs LOG	
Status:	Done
Open - Closed - Active - ON - LOG	
Status:	Done
Switch 1:	False
Switch 2:	True
Disable Outputs LOG	
Status:	Done
Check Outputs	
Status:	Failed
Configuration:	TRIP true
Output_1_SIG:	True
Output_2_AUX:	False

Additional Results	
Status:	Done

Configuration:	How is the status of LED?
Fix_Red:	FIX RED
Additional Results	
Status:	Done
Configuration:	How is the status of MDP?
Status:	UNLOCKED

End Sequence: TRIP - Switch1 open - Switch2 closed

End Sequence: MainSequence

End UUT Report

---