

UUT Report

Station ID: IT-W-7303101
Serial Number: NONE
Date: lunedì 6 novembre 2023
Time: 14:54:09
Operator: administrator
Execution Time: 232.7043004 seconds
Number of Results: 245
UUT Result: Passed
Product: ARI LV
Product type: NO COMM
Comm type: NO COMM
Product FW Version: NO COMM
Comm FW Version: NO COMM



Begin Sequence: MainSequence
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)

Simultaneous trip_open	
Status:	Skipped
General and Architecture and LED	
Status:	Skipped
Input-Output	
Status:	Passed
Module Time:	224.3820841

Begin Sequence: I/O
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)

Additional Results	
Status:	Done
PopupString:	Check that remote closing hasn't appened.
Status:	Passed
Additional Results	
Status:	Done
PopupString:	Check that remote closing hasn't appened.
Status:	Passed
Additional Results	
Status:	Done
PopupString:	Check that remote opening hasn't appened.
Status:	Passed
Additional Results	
Status:	Done
PopupString:	Check that remote opening hasn't appened.
Status:	Passed
Check Outputs	
Status:	Passed
Configuration:	MOD in Active State and MPD OPEN
Output 1:	False
Output 2:	True
Additional Results	

Status:	Done
PopupString:	Check that remote opening worked.
Status:	Passed
Check Outputs	
Status:	Passed
Configuration:	MOD in Active State and MPD OPEN
Output 1:	False
Output 2:	False
Check Outputs	
Status:	Passed
Configuration:	MOD in Active State and MPD OPEN
Output 1:	False
Output 2:	False
Check Outputs	
Status:	Passed
Configuration:	MOD in Active State and MPD HALF OPEN
Output 1:	False
Output 2:	True
Check Outputs	
Status:	Passed
Configuration:	MOD in Active State and MPD HALF OPEN
Output 1:	False
Output 2:	True
Additional Results	
Status:	Done
PopupString:	Check that remote closing worked.
Status:	Passed

Check Outputs stand-by	
Status:	Passed
Configuration:	MOD in Lock State
Output 1:	False
Output 2:	True
Additional Results	
Status:	Done
PopupString:	Check that closing has not worked due to input command but for the auto-reclosing.
Status:	Passed
Additional Results	
Status:	Done
PopupString:	Check ARI is in Lock state.
Status:	Passed
Check Outputs	
Status:	Passed
Configuration:	MOD in Lock State
Output 1:	True
Output 2:	False
Check Outputs	
Status:	Passed
Configuration:	MOD in Lock State
Output 1:	False
Output 2:	True
Additional Results	
Status:	Done

PopupString:	Check that remote closing not worked.
Status:	Passed

End Sequence: I/O

Power Outage	
Status:	Skipped
Motor Driver	
Status:	Skipped

End Sequence: MainSequence

End UUT Report

