

UUT Report

Station ID: IT-W-7303101
Serial Number: M086AB1000
Date: lunedì 29 maggio 2023
Time: 11:48:34
Operator: administrator
Execution Time: 1506.8533848 seconds
Number of Results: 207
UUT Result: Passed

Begin Sequence: MainSequence

(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\M4M\PMD-4540_Reactive.seq)

DUT recap	
Status:	Done
Serial Number:	M086AB1000
Type Designator:	M4M31SEA
FW Version:	P3.0.0.4
PMD-1121	
Status:	Passed
Module Time:	1506.7818983

Begin Sequence: PMD-1121

(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\M4M\PMD-4540_Reactive.seq)

Pass/Fail Test Slot 2	
Status:	Passed
Pass/Fail Test Slot 3	
Status:	Passed
Pass/Fail Test Slot 4	
Status:	Passed
Additional Results	
Status:	Done
Import:	0
Export:	0
Import Delay:	0.05
Export Delay:	0
Pass/Fail Test T1 Import	
Status:	Passed
Measurement:	0.05
Limits:	
Low:	0.008
Comparison Type:	GE (>=)
Pass/Fail Test T1 Export	
Status:	Passed
Measurement:	0
Limits:	

Low:	0.032
Comparison Type:	LE (<=)
Additional Results	
Status:	Done
Import:	0.05
Export:	0
Import Delay:	0.05
Export Delay:	0.05
Pass/Fail Test T1 Export	
Status:	Passed
Measurement:	0.05
Limits:	
Low:	0.008
Comparison Type:	GE (>=)
Pass/Fail Test T1 Import	
Status:	Passed
Measurement:	0
Limits:	
Low:	0.032
Comparison Type:	LE (<=)
Additional Results	
Status:	Done
Import:	0.01
Export:	0.01
Import Delay:	0.06
Export Delay:	0.01
Pass/Fail Test T2 Import	
Status:	Passed
Measurement:	0.05
Limits:	
Low:	0.008
Comparison Type:	GE (>=)
Pass/Fail Test T2 Export	
Status:	Passed
Measurement:	0
Limits:	
Low:	0.032
Comparison Type:	LE (<=)
Additional Results	
Status:	Done
Import:	0.06
Export:	0.01
Import Delay:	0.06
Export Delay:	0.06
Pass/Fail Test T2 Export	
Status:	Passed
Measurement:	0.05
Limits:	
Low:	0.008
Comparison Type:	GE (>=)

Pass/Fail Test T2 Import	
Status:	Passed
Measurement:	0
Limits:	
Low:	0.032
Comparison Type:	LE (<=)
Additional Results	
Status:	Done
Import:	0
Export:	0
Import Delay:	0.05
Export Delay:	0
Pass/Fail Test T3 Import	
Status:	Passed
Measurement:	0.05
Limits:	
Low:	0.008
Comparison Type:	GE (>=)
Pass/Fail Test T3 Export	
Status:	Passed
Measurement:	0
Limits:	
Low:	0.032
Comparison Type:	LE (<=)
Additional Results	
Status:	Done
Import:	0.05
Export:	0
Import Delay:	0.05
Export Delay:	0.05
Pass/Fail Test T3 Export	
Status:	Passed
Measurement:	0.05
Limits:	
Low:	0.008
Comparison Type:	GE (>=)
Pass/Fail Test T3 Import	
Status:	Passed
Measurement:	0
Limits:	
Low:	0.032
Comparison Type:	LE (<=)
Additional Results	
Status:	Done
Import:	0
Export:	0
Import Delay:	0.05
Export Delay:	0
Pass/Fail Test T4 Import	
Status:	Passed

Measurement:	0.05
Limits:	
Low:	0.008
Comparison Type:	GE (>=)
Pass/Fail Test T4 Export	
Status:	Passed
Measurement:	0
Limits:	
Low:	0.032
Comparison Type:	LE (<=)
Additional Results	
Status:	Done
Import:	0.05
Export:	0
Import Delay:	0.05
Export Delay:	0.05
Pass/Fail Test T4 Export	
Status:	Passed
Measurement:	0.05
Limits:	
Low:	0.008
Comparison Type:	GE (>=)
Pass/Fail Test T4 Import	
Status:	Passed
Measurement:	0
Limits:	
Low:	0.032
Comparison Type:	LE (<=)
Additional Results	
Status:	Done
Import:	0
Export:	0
Import Delay:	0.05
Export Delay:	0
Pass/Fail Test T5 Import	
Status:	Passed
Measurement:	0.05
Limits:	
Low:	0.008
Comparison Type:	GE (>=)
Pass/Fail Test T5 Export	
Status:	Passed
Measurement:	0
Limits:	
Low:	0.032
Comparison Type:	LE (<=)
Additional Results	
Status:	Done
Import:	0.05
Export:	0

Import Delay:	0.05
Export Delay:	0.05
Pass/Fail Test T5 Export	
Status:	Passed
Measurement:	0.05
Limits:	
Low:	0.008
Comparison Type:	GE (>=)
Pass/Fail Test T5 Import	
Status:	Passed
Measurement:	0
Limits:	
Low:	0.032
Comparison Type:	LE (<=)
Additional Results	
Status:	Done
Import:	0
Export:	0
Import Delay:	0.05
Export Delay:	0
Pass/Fail Test T6 Import	
Status:	Passed
Measurement:	0.05
Limits:	
Low:	0.008
Comparison Type:	GE (>=)
Pass/Fail Test T6 Export	
Status:	Passed
Measurement:	0
Limits:	
Low:	0.032
Comparison Type:	LE (<=)
Additional Results	
Status:	Done
Import:	0.05
Export:	0
Import Delay:	0.05
Export Delay:	0.05
Pass/Fail Test T6 Export	
Status:	Passed
Measurement:	0.05
Limits:	
Low:	0.008
High:	0.072
Comparison Type:	GELE (>= <=)
Pass/Fail Test T6 Import	
Status:	Passed
Measurement:	0
Limits:	
Low:	0.032

Comparison Type:

LE (\leq)

End Sequence: PMD-1121

End Sequence: MainSequence

End UUT Report
