

UUT Report

Station ID: IT-W-7303101  
Serial Number: NONE  
Date: mercoledì 8 novembre 2023  
Time: 10:01:58  
Operator: administrator  
Execution Time: 163.9355772 seconds  
Number of Results: 161  
UUT Result: Failed  
Product: ARI-30  
Product type: ARI-30  
Comm type: COMM1\_RS485  
Product FW Version: 56010807  
Comm FW Version: 56010000  
Failure Chain:

Step	Sequence	Sequence File
<a href="#">Check Half open</a>	Power Outage	General_test.seq
<a href="#">Power Outage</a>	MainSequence	General_test.seq



Begin Sequence: MainSequence  
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD\_Shared\TestStand\Sequences\MOD\General\_test.seq)

Double_trip_ARI_blocked	
Status:	Skipped
Simultaneous trip_open	
Status:	Skipped
General and Architecture and LED	
Status:	Skipped
Input-Output	
Status:	Skipped
Power Outage	
Status:	Failed
Module Time:	154.0336386

Begin Sequence: Power Outage  
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD\_Shared\TestStand\Sequences\MOD\General\_test.seq)

Check Half open	
Status:	Failed
Additional Results	
Status:	Done
PopupString:	Check that the MOD open automatically the MPD at power On without reclosing.
Status:	Passed
Additional Results	
Status:	Skipped
Additional Results	
Status:	Done

PopupString:	Check that the MOD closes automatically the MPD at power On after power fail.
Status:	Passed
Additional Results	
Status:	Done
PopupString:	Check that the MOD open automatically the MPD at power On and reclose without dead time.
Status:	Passed

End Sequence: Power Outage

Motor Driver	
Status:	Skipped

Modbus Register check	
Status:	Skipped
Modbus settings check	
Status:	Skipped
COMM LED & Button	
Status:	Skipped
Firmware Upgrade	
Status:	Skipped

End Sequence: MainSequence

End UUT Report

