

UUT Report

Station ID:

Serial Number:

Date:

Time:

Operator:

Execution Time:

Number of Results:

UUT Result:

IT-W-7303101

NONE

mercoledì 22 marzo 2023

10:43:03

ITLAVIT1

00:06:44.073

135

Terminated

Begin Sequence: MainSequence
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\MOD\Complete_test_modified_Germany.seq)

UUT Parameters	
Status:	Done
TestResults/Data:	
Product Name:	MOD LV
Communication Module:	NONE
UUT_info_comm	
Status:	Done
TestResults/Data:	
Product type:	"
COMM type:	"
Product Firmware version:	"
COMM Firmware version:	"
General and Architecture and LED	
Status:	Passed
Module Time:	218.35

Begin Sequence: General and Architecture and LED
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\MOD\Complete_test_modified_Germany.seq)

Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that manual opening and closing of the device shall be possible when the device is power off and the LED is OFF.
Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that manual opening and closing of the device shall be possible when the device is power ON and in NOT-Active state.
Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that the LED is "Blinking Green" in both active and close configurations.
Status:	Passed
Additional Results	

Status:	Done
TestResults/Data:	
PopupString:	Check that the LED is "Blinking Green".
Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that manual opening and closing of the device shall be possible when the device is power ON and in NOT-Active state.
Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that the LED is "Blinking Green" in both active and close configurations.
Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that the LED is "Blinking Green".
Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that the LED is "Blinking Green" in both active and close configurations.
Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that manual opening and closing of the device shall be possible when the device is power ON and in Active state.
Status:	Passed

Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that the LED is "Fix Green" in both active and close configurations.
Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that the LED is "Fix Green".
Status:	Passed

Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that manual opening and closing of the device shall be possible when the device is power ON and in Active state.
Status:	Passed

Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that the LED is "Fix Green" in both active and close configurations.

Status:	Passed
---------	--------

Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that the LED is "Fix Green".
Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that manual opening and closing of the device shall be possible when the device is power ON and in Active state.
Status:	Passed

Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that the LED is "Fix Green" in both active and close configurations.
Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that the LED is "Fix Red".
Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that manual opening and closing of the device shall be possible when the device is power ON and in Locked state.
Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that the LED is "Fix Green".
Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that the LED is "Fix Red".
Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that manual opening and closing of the device shall be possible when the device is power ON and in Locked state.
Status:	Passed

End Sequence: General and Architecture and LED

Input-Output	
Status:	Terminated
Module Time:	183.329

Begin Sequence: I/O
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\MOD\Complete_test_modified_Germany.seq)

Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that remote closing hasn't appened.
Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that remote closing hasn't appened.
Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that remote opening hasn't appened.
Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that remote opening hasn't appened.
Status:	Passed
Check Outputs	
Status:	Failed
TestResults/Data:	
Configuration:	MOD in Active State and MPD OPEN
Output 1:	False
Output 2:	True

End Sequence: I/O

End Sequence: MainSequence

End UUT Report

