UUT Report

Station ID: IT-W-7303101

Serial Number: NONE

Date: lunedì 6 marzo 2023

Time: 14:16:09

Operator: ITLAVIT1

Execution Time: 00:00:12.333

Number of Results: 14

UUT Result:

Error, Error executing substep 'Run'.
Error 56 occurred at IPSES_Modbus_x64.lvlibp:RTU Data Unit.lvclass:Read ADU Packet.vi:5030001

Possible reason(s):

LabVIEW: (Hex 0x38) The network operation exceeded the user-specified or system time limit.
LabVIEW: (Hex 0x38) The network operation exceeded the user-specified or system time limit.
[Error Code: 56, User-defined error code.]

End UUT Report