

# UUT Report

Station ID: IT-W-7303101  
Serial Number: NONE  
Date: giovedì 30 marzo 2023  
Time: 12:25:48  
Operator: ITLAVIT1  
Execution Time: 00:00:08.466  
Number of Results: 24  
UUT Result: Passed

Begin Sequence: MainSequence  
(C:\Users\itlavit1\OneDrive - ABB\LabRnD\_Shared\TestStand\Sequences\M4M\PMD-4455.seq)

DUT recap	
Status:	Done
TestResults/Data:	
Serial Number:	Q032AB102T
Type Designator:	M4M30SMA
FW Version:	P3.0.0.3

PMD-4455	
Status:	Skipped
PMD-1179 = 4455	
Status:	Passed
Module Time:	8.34117

Begin Sequence: PMD-1179  
(C:\Users\itlavit1\OneDrive - ABB\LabRnD\_Shared\TestStand\Sequences\M4M\PMD-1179.seq)

Set PhaseVoltage - LOG	
Status:	Done
TestResults/Data:	
HMI - Phase Voltage Unbalance:	8.8
Set Line Voltage - LOG	
Status:	Done
TestResults/Data:	
HMI - Line Voltage Unbalance:	4.3
Set Current - LOG	
Status:	Done
TestResults/Data:	
HMI - Current Unbalance:	39.8
Numeric Limit Test - Phase Unbalance	
Status:	Passed
Numeric:	0.2909090909091
Limits:	

Low:	-0.9090909090909
High:	0.9090909090909
Comparison Type:	GELE(>= <=)
Numeric Limit Test - Current Unbalance	
Status:	Passed
Numeric:	0.2
Limits:	
Low:	-4
High:	4
Comparison Type:	GELE(>= <=)

**End Sequence: PMD-1179**

**End Sequence: MainSequence**

**End UUT Report**

---