UUT Report

Station ID:	**IT-W-7303101**
Serial Number:	**NONE**
Date:	**lunedì 20 marzo 2023**
Time:	**10:51:44**
Operator:	**ITLAVIT1**
Execution Time:	**00:02:28.051**
Number of Results:	**410**
UUT Result:	**Terminated**

Begin Sequence: MainSequence
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\M4M\PMD-4444.seq)

DUT recap	
Status:	Done
TestResults/Data:	
Serial Number:	M086AB1000
Type Designator:	M4M30SEA
FW Version:	P3.0.0.3
Reset installation settings	
Status:	Passed
Module Time:	0.632481
Alarms Init	
Status:	Passed
Module Time:	7.33929

Begin Sequence: Alarms_Init
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\M4M\PMD-4444.seq)

COMM - Reset Alarms	
Status:	Passed
Module Time:	1.0401

Touch - Go Home	
Status:	Skipped
Touch - Reset Notifications	
Status:	Skipped
Touch - Go Home	
Status:	Skipped

End Sequence: Alarms_Init

1 Alarm N Slots	
Status:	Terminated

Parameters	
AlarmNumber:	1
Module Time:	139.211

Begin Sequence: 1AlarmNSlots
(C:\Users\itlavit1\OneDrive –
ABB\LabRnD_Shared\TestStand\Sequences\M4M\PMD-4444.seq)

Additional Results	
Status:	Done
TestResults/Data:	
Slot number:	1
COMM - Reset Alarms	
Status:	Passed
Module Time:	0.803656
COMM - Reset Slots	
Status:	Passed
Module Time:	0.160605
Check a simple alarm via Modbus	
Status:	Passed
Check simple alarm - Omicron - Alarm Triggered	
Status:	Failed
Check a simple alarm via Modbus flags	
Status:	Passed
Check simple alarm - Modbus - IO - Alarm Triggered	
Status:	Passed

Touch Go Warnings Shortcut	
Status:	Passed
Module Time:	6.92601
Touch - Go Home	
Status:	Passed
Module Time:	16.5722

Begin Sequence: Touch_GoHome
(C:\Users\itlavit1\OneDrive –
ABB\LabRnD_Shared\TestStand\Sequences\M4M\CommonUtilitySequences.seq)

Pass/Fail - Home Reached	
Status:	Passed

End Sequence: Touch_GoHome

Check simple alarm - Omicron - No Alarm	
Status:	Passed
Check a simple alarm via Modbus flags	
Status:	Passed
Check simple alarm - Modbus - IO - No Alarm	

Status:	Passed

Image ROI Matching - Alarm Icon	
Status:	Failed
Touch Go Warnings Shortcut	
Status:	Skipped
Touch - Go Home	
Status:	Skipped

Additional Results	
Status:	Done
TestResults/Data:	
Slot number:	2
COMM - Reset Alarms	
Status:	Passed
Module Time:	0.844302
COMM - Reset Slots	
Status:	Passed
Module Time:	0.13022
Check a simple alarm via Modbus	
Status:	Passed
Check simple alarm - Omicron - Alarm Triggered	
Status:	Failed
Check a simple alarm via Modbus flags	
Status:	Passed
Check simple alarm - Modbus - IO - Alarm Triggered	
Status:	Passed

End Sequence: 1AlarmNSlots

End Sequence: MainSequence

End UUT Report