

UUT Report

Station ID: IT-W-7303101
Serial Number: M086AB1000
Date: martedì 21 marzo 2023
Time: 15:57:07
Operator: ITLAVIT1
Execution Time: 00:00:37.096
Number of Results: 31
UUT Result: Terminated

Begin Sequence: MainSequence
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\M4M\PMD-1883.seq)

DUT recap	
Status:	Done
TestResults/Data:	
Serial Number:	M086AB1000
Type Designator:	M4M30SEA
FW Version:	P3.0.0.3
Pulse Output 1 and 2	
Status:	Terminated
Module Time:	37.0415

Begin Sequence: Pulse Output 1 and 2
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\M4M\PMD-1883.seq)

Pass/Fail Test	
Status:	Passed
Pass/Fail Test	
Status:	Passed
Active energy pulses check	
Status:	Failed
Numeric:	0
Limits:	
Low:	78
High:	88
Comparison Type:	GELE(>= <=)

End Sequence: Pulse Output 1 and 2

End Sequence: MainSequence

End UUT Report
