UUT Report

Station ID:	**IT-W-7303101**
Serial Number:	**NONE**
Date:	**venerdì 17 febbraio 2023**
Time:	**11:18:22**
Operator:	**ITLAVIT1**
Execution Time:	**00:03:28.071**
Number of Results:	**116**
UUT Result:	**Passed**

Begin Sequence: MainSequence
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\MOD\Input-Output\MOD I-O.seq)

Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that remote closing hasn't appened.
Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that remote closing hasn't appened.
Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that remote opening hasn't appened.
Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that remote opening hasn't appened.
Status:	Passed
Check MOD Outputs	
Status:	Passed
TestResults/Data:	
Configuration:	MOD in Active State and MPD CLOSED
Output 1:	True
Output 2:	True
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that the simultaneous opening and closing command does not affect the MOD configuration.
Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that remote opening worked.
Status:	Passed
Check MOD Outputs	

Status:	Passed
TestResults/Data:	
Configuration:	MOD in Active State and MPD OPEN
Output 1:	False
Output 2:	True
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that the simultaneous opening and closing command does not affect the MOD configuration.
Status:	Passed
Check MOD Outputs	
Status:	Passed
TestResults/Data:	
Configuration:	MOD in Active State and MPD OPEN
Output 1:	False
Output 2:	True
Check MOD Outputs	
Status:	Passed
TestResults/Data:	
Configuration:	MOD in Active State and MPD HALF OPEN
Output 1:	True
Output 2:	True
Check MOD Outputs	
Status:	Passed
TestResults/Data:	
Configuration:	MOD in Active State and MPD HALF OPEN
Output 1:	True
Output 2:	True
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that remote closing worked.
Status:	Passed
Check MOD Outputs	
Status:	Passed
TestResults/Data:	
Configuration:	MOD in Lock State
Output 1:	False
Output 2:	False
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that the simultaneous opening and closing command does not affect the MOD configuration.
Status:	Passed
Check MOD Outputs	
Status:	Passed
TestResults/Data:	
Configuration:	MOD in Lock State
Output 1:	False
Output 2:	False
Additional Results	
Status:	Done

TestResults/Data:	
PopupString:	Check that remote closing worked.
Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that remote closing has not appened due to Dead time of 8 seconds after the trip.
Status:	Passed
Additional Results	
Status:	Done
TestResults/Data:	
PopupString:	Check that remote closing has appened after the Dead time of 8 seconds after the trip.
Status:	Passed

End Sequence: MainSequence

End UUT Report