# UUT Report

| | |
|---|---|
| **Station ID:** | IT-W-7303101 |
| **Serial Number:** | NONE |
| **Date:** | **lunedì 2 ottobre 2023** |
| **Time:** | **10:30:06** |
| **Operator:** | administrator |
| **Execution Time:** | **215.637617 seconds** |
| **Number of Results:** | **126** |
| **UUT Result:** | **Terminated** |
| **Product:** | **ARI LV** |
| **Product type:** | **ARI HV** |
| **Comm type:** | **COMM1_RS485** |
| **Product FW Version:** | **56010802** |
| **Comm FW Version:** | **56010000** |

---

**Begin Sequence: MainSequence**
**(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)**

| General and Architecture and LED | |
|---|---|
| Status: | Skipped |

| Input-Output | |
|---|---|
| Status: | Skipped |

| Power Outage | |
|---|---|
| Status: | Passed |
| Module Time: | 145.6094585 |

**Begin Sequence: Power Outage**
**(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)**

| Additional Results | |
|---|---|
| Status: | Done |
| PopupString: | Check that the MOD open automatically the MPD at power On without reclosing. |
| Status: | Passed |

| Additional Results | |
|---|---|
| Status: | Skipped |

| Additional Results | |
|---|---|
| Status: | Done |
| PopupString: | Check that the MOD closes automatically the MPD at power On after power fail. |
| Status: | Passed |

| Additional Results | |
|---|---|
| Status: | Done |
| PopupString: | Check that the MOD open automatically the MPD at power On and reclose without dead time. |
| Status: | Passed |

**End Sequence: Power Outage**

| Motor Driver | |
|---|---|
| Status: | Terminated |
| | |

| Module Time: | 24.1090038 |
| --- | --- |

**Begin Sequence: Motor Driver
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)**

| MPD MODEL | |
| --- | --- |
| Status: | Done |
| MPD MODEL: | '' |

**End Sequence: Motor Driver**

**End Sequence: MainSequence**

# End UUT Report