UUT Report

Station ID:	IT-W-7303101
Serial Number:	NONE
Date:	**martedì 17 ottobre 2023**
Time:	**10:25:08**
Operator:	administrator
Execution Time:	40.8152593 seconds
Number of Results:	38
UUT Result:	**Terminated**
Product:	ARI LV
Product type:	ARI LV
Comm type:	COMM1_RS485
Product FW Version:	56010804
Comm FW Version:	56010000

Begin Sequence: MainSequence
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\FMEA.seq)

Initial state closed	
Status:	Passed
Module Time:	9.1245677

Begin Sequence: Initial State closed
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\FMEA.seq)

Read Outputs LOG	
Status:	Done
Output_1_SIG:	True
Output_2_AUX:	False

End Sequence: Initial State closed

TRIP - Switch1 open - Switch2 closed	
Status:	Passed
Module Time:	13.5085162

Begin Sequence: TRIP - Switch1 open - Switch2 closed
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\FMEA.seq)

Check Outputs	
Status:	Passed
Configuration:	TRIP true
Output 1:	False
Output 2:	False

End Sequence: TRIP - Switch1 open - Switch2 closed

Close command and Switch1 closed - Switch2 open	
Status:	Terminated
Module Time:	17.4318107

End Sequence: MainSequence

End UUT Report