UUT Report

Station ID:	IT-W-7303101
Serial Number:	NONE
Date:	mercoledì 11 ottobre 2023
Time:	14:10:03
Operator:	administrator
Execution Time:	147.4976899 seconds
Number of Results:	129
UUT Result:	**Passed**
Product:	MOD LV
Product type:	MOD LV
Comm type:	COMM1_RS485
Product FW Version:	56010804
Comm FW Version:	56010000

Begin Sequence: MainSequence
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)

General and Architecture and LED	
Status:	Skipped

Input-Output	
Status:	Passed
Module Time:	133.0770078

Begin Sequence: I/O
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)

Additional Results	
Status:	Done
PopupString:	Check that remote closing hasn't appened.
Status:	Passed

Additional Results	
Status:	Done
PopupString:	Check that remote closing hasn't appened.
Status:	Passed

Additional Results	
Status:	Done
PopupString:	Check that remote opening hasn't appened.
Status:	Passed

Additional Results	
Status:	Done
PopupString:	Check that remote opening hasn't appened.
Status:	Passed

Check Outputs	
Status:	Passed
Configuration:	MOD in Active State and MPD OPEN
Output 1:	True
Output 2:	False

Additional Results	
Status:	Done
PopupString:	Check that remote opening worked.

Status:	Passed

Check Outputs

Status:	Passed
Configuration:	MOD in Active State and MPD OPEN
Output 1:	False
Output 2:	False

Check Outputs

Status:	Passed
Configuration:	MOD in Active State and MPD OPEN
Output 1:	False
Output 2:	False

Check Outputs

Status:	Passed
Configuration:	MOD in Active State and MPD HALF OPEN
Output 1:	True
Output 2:	False

Check Outputs

Status:	Passed
Configuration:	MOD in Active State and MPD HALF OPEN
Output 1:	True
Output 2:	False

Additional Results

Status:	Done
PopupString:	Check that remote closing worked.
Status:	Passed

Check MOD Outputs

Status:	Passed
Configuration:	MOD in Lock State
Output 1:	False
Output 2:	True

Check MOD Outputs

Status:	Passed
Configuration:	MOD in Lock State
Output 1:	False
Output 2:	True

Additional Results

Status:	Done
PopupString:	Check that remote closing worked.
Status:	Passed

Additional Results

Status:	Done
PopupString:	Check that remote closing has not appened due to Dead time of 8 seconds after the trip.
Status:	Passed

Additional Results

Status:	Done
PopupString:	Check that remote closing has appened after the Dead time of 8 seconds after the trip.
Status:	Passed

End Sequence: I/O

Power Outage

Status:	Skipped

Motor Driver	
Status:	Skipped

Modbus Register check	
Status:	Skipped
Modbus settings check	
Status:	Skipped
COMM LED & Button	
Status:	Skipped
Firmware Upgrade	
Status:	Skipped

End Sequence: MainSequence

End UUT Report