

UUT Report

Station ID: IT-W-7303101
Serial Number: NONE
Date: martedì 14 novembre 2023
Time: 16:21:00
Operator: administrator
Execution Time: 3152.9177292 seconds
Number of Results: 298
UUT Result: Terminated
Product: ARI LV
Product type: NO COMM
Comm type: NO COMM
Product FW Version: NO COMM
Comm FW Version: NO COMM

Begin Sequence: MainSequence

(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)

Double_trip_ARI_blocked	
Status:	Skipped
Simultaneous trip_open	
Status:	Skipped
General and Architecture and LED	
Status:	Skipped
Input-Output	
Status:	Skipped
Power Outage	
Status:	Terminated
Module Time:	3145.8163728

Begin Sequence: Power Outage

(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)

Additional Results	
Status:	Done
PopupString:	Check that the MOD open automatically the MPD at power On without reclosing.
Status:	Passed
Additional Results	
Status:	Done
PopupString:	Check that the MOD open automatically the MPD at power On without reclosing.
Status:	Passed
Additional Results	
Status:	Done
PopupString:	Check that the MOD closes automatically the MPD at power On after power fail.
Status:	Passed
Additional Results	
Status:	Skipped
Check Half open	
Status:	Failed

Check open and reclose	
Status:	Failed
Additional Results	
Status:	Done
PopupString:	Check that the MOD closes automatically the MPD at power On after power fail.
Status:	Failed
Additional Results	
Status:	Skipped
Check Half open	
Status:	Failed
Additional Results	
Status:	Done
PopupString:	Check that the MOD open automatically the MPD at power On without reclosing.
Status:	Passed

End Sequence: Power Outage

End Sequence: MainSequence

End UUT Report

