

UUT Report

Station ID: IT-W-7303101  
Serial Number: NONE  
Date: venerdì 27 ottobre 2023  
Time: 11:20:44  
Operator: administrator  
Execution Time: 561.6116405 seconds  
Number of Results: 181  
**Error**, Error executing substep 'Run'.  
Error 56 occurred at IPSES\_Modbus\_x86.lvlibp:RTU Data Unit.lvclass:Read ADU Packet.vi:5030001

UUT Result: Possible reason(s):  
  
LabVIEW: (Hex 0x38) The network operation exceeded the user-specified or system time limit.  
LabVIEW: (Hex 0x38) The network operation exceeded the user-specified or system time limit.  
[Error Code: 56, User-defined error code.]  
  
Product: MOD LV  
Product type: MOD HV  
Comm type: COMM1\_RS485  
Product FW Version: 56010805  
Comm FW Version: 56010000

Begin Sequence: MainSequence  
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD\_Shared\TestStand\Sequences\MOD\General\_test.seq)

Simultaneous trip_open	
Status:	Skipped
General and Architecture and LED	
Status:	Skipped
Input-Output	
Status:	Failed
Module Time:	142.2669753

Begin Sequence: I/O  
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD\_Shared\TestStand\Sequences\MOD\General\_test.seq)

Additional Results	
Status:	Done
PopupString:	Check that remote closing hasn't appened.
Status:	Passed
Additional Results	
Status:	Done
PopupString:	Check that remote closing hasn't appened.
Status:	Passed
Additional Results	
Status:	Done
PopupString:	Check that remote opening hasn't appened.
Status:	Passed
Additional Results	
Status:	Done
PopupString:	Check that remote opening hasn't appened.
Status:	Passed

Check Outputs	
Status:	Failed
Configuration:	MOD in Active State and MPD OPEN
Output 1:	True
Output 2:	True
Check Remote Open	
Status:	Failed
Additional Results	
Status:	Done
PopupString:	Check that remote opening worked.
Status:	Failed
Check Outputs	
Status:	Failed
Configuration:	MOD in Active State and MPD OPEN
Output 1:	True
Output 2:	True
Check Outputs	
Status:	Failed
Configuration:	MOD in Active State and MPD OPEN
Output 1:	True
Output 2:	True
Check Outputs	
Status:	Failed
Configuration:	MOD in Active State and MPD HALF OPEN
Output 1:	True
Output 2:	True
Check Outputs	
Status:	Failed
Configuration:	MOD in Active State and MPD HALF OPEN
Output 1:	True
Output 2:	True
Additional Results	
Status:	Done
PopupString:	Check that remote closing worked.
Status:	Passed

Check MOD Outputs	
Status:	Failed
Configuration:	MOD in Lock State
Output 1:	True
Output 2:	True
Check MOD Outputs	
Status:	Failed
Configuration:	MOD in Lock State
Output 1:	True
Output 2:	True
Check Remote Close	
Status:	Failed
Additional Results	
Status:	Done
PopupString:	Check that remote closing worked.
Status:	Failed

Additional Results	
Status:	Done
PopupString:	Check that remote closing has not appened due to Dead time of 8 seconds after the trip.
Status:	Passed
Additional Results	
Status:	Done
PopupString:	Check that remote closing has appened after the Dead time of 8 seconds after the trip.
Status:	Passed

End Sequence: I/O

Power Outage	
Status:	Passed
Module Time:	67.8117048

Begin Sequence: Power Outage  
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD\_Shared\TestStand\Sequences\MOD\General\_test.seq)

Additional Results	
Status:	Done
PopupString:	Check that the MOD open automatically the MPD at power On without reclosing.
Status:	Passed
Additional Results	
Status:	Skipped

End Sequence: Power Outage

Motor Driver	
Status:	Skipped

Modbus Register check	
Status:	Error
Error Message: Error executing substep 'Run'. Error 56 occurred at IPSES_Modbus_x86.lvlibp:RTU Data Unit.lvclass:Read ADU Packet.vi:5030001	
Possible reason(s):  LabVIEW: (Hex 0x38) The network operation exceeded the user-specified or system time limit. LabVIEW: (Hex 0x38) The network operation exceeded the user-specified or system time limit. [Error Code: 56]	
Module Time:	58.3227917

End Sequence: MainSequence

End UUT Report

