UUT Report

Station ID:	IT-W-7303101
Serial Number:	NONE
Date:	**lunedì 30 ottobre 2023**
Time:	10:56:47
Operator:	administrator
Execution Time:	123.522957 seconds
Number of Results:	43
UUT Result:	**Terminated**
Product:	MOD LV
Product type:	MOD HV
Comm type:	COMM1_RS485
Product FW Version:	56010805
Comm FW Version:	56010000

Begin Sequence: MainSequence
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)

Simultaneous trip_open	
Status:	Skipped

General and Architecture and LED	
Status:	Skipped

Input-Output	
Status:	Skipped

Power Outage	
Status:	Skipped

Motor Driver	
Status:	Skipped

Modbus Register check	
Status:	Terminated
Module Time:	106.2963015

Begin Sequence: Modbus Register check
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\General_test.seq)

Internal communication failure	
Status:	Done
Register Value:	OK

Additional Results	
Status:	Done
PopupString:	Check that the remote opening via modbus worked.
Status:	Passed

Additional Results	
Status:	Done
PopupString:	Check that the remote closing via modbus worked.
Status:	Passed

Popup PassFail	
Status:	Failed

Additional Results	
Status:	Done
PopupString:	Check that the remote closing via modbus has not worked during dead time.
Status:	Failed

End Sequence: Modbus Register check

End Sequence: MainSequence

End UUT Report