

UUT Report

Station ID:

Serial Number:

Date:

Time:

Operator:

Execution Time:

Number of Results:

UUT Result:

IT-W-7303101

M086AB1000

lunedì 29 maggio 2023

16:41:53

administrator

95.8709629 seconds

38

Passed

Begin Sequence: MainSequence
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\M4M\PMD-1883.seq)

DUT recap	
Status:	Done
Serial Number:	M086AB1000
Type Designator:	M4M20SEA
FW Version:	P3.0.0.4
Pulse Output 1 and 2	
Status:	Passed
Module Time:	95.7436109

Begin Sequence: Pulse Output 1 and 2
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\M4M\PMD-1883.seq)

Pass/Fail Test	
Status:	Passed
Pass/Fail Test	
Status:	Passed
Active energy pulses check	
Status:	Passed
Measurement:	83
Limits:	
Low:	78
High:	88
Comparison Type:	GELE (>= <=)
Active energy pulses check	
Status:	Passed
Measurement:	47
Limits:	
Low:	43
High:	53
Comparison Type:	GELE (>= <=)

End Sequence: Pulse Output 1 and 2

End Sequence: MainSequence

