

UUT Report

Station ID: IT-W-7303101
Serial Number: NONE
Date: giovedì 30 marzo 2023
Time: 09:56:41
Operator: ITLAVIT1
Execution Time: 00:00:46.592
Number of Results: 57
UUT Result: Passed

Begin Sequence: MainSequence
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\M4M\PM-1178.seq)

| | |
|-------------------|------------|
| DUT recap | |
| Status: | Done |
| TestResults/Data: | |
| Serial Number: | Q032AB102T |
| Type Designator: | M4M30SMA |
| FW Version: | P3.0.0.3 |

| | |
|--------------|---------|
| PMD-1178 | |
| Status: | Passed |
| Module Time: | 46.3803 |

Begin Sequence: PMD-1178
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\M4M\PM-1178.seq)

| | |
|--------------------------------|---------|
| Touch - Go Home | |
| Status: | Skipped |
| Touch - Go To Power Quality | |
| Status: | Passed |
| Module Time: | 5.28673 |
| Set PhaseVoltage - LOG | |
| Status: | Done |
| TestResults/Data: | |
| HMI - Phase Voltage Unbalance: | 8.8 |
| Set Line Voltage - LOG | |
| Status: | Done |
| TestResults/Data: | |
| HMI - Line Voltage Unbalance: | 4.3 |
| Set Current - LOG | |
| Status: | Done |
| TestResults/Data: | |
| HMI - Current Unbalance: | 39.9 |

| | |
|---|------------------|
| Numeric Limit Test - Phase Unbalance Difference | |
| Status: | Passed |
| Numeric: | 0.2909090909091 |
| Limits: | |
| Low: | -0.9090909090909 |
| High: | 0.9090909090909 |
| Comparison Type: | GELE(>= <=) |
| Numeric Limit Test - Current Unbalance Difference | |
| Status: | Passed |
| Numeric: | 0.1 |
| Limits: | |
| Low: | -4 |
| High: | 4 |
| Comparison Type: | GELE(>= <=) |

End Sequence: PMD-1178

End Sequence: MainSequence

End UUT Report
