UUT Report

Station ID:	IT-W-7303101
Serial Number:	NONE
Date:	martedì 17 ottobre 2023
Time:	11:36:19
Operator:	administrator
Execution Time:	402.2888491 seconds
Number of Results:	235
UUT Result:	**Failed**
Product:	ARI LV
Product type:	ARI LV
Comm type:	COMM1_RS485
Product FW Version:	56010804
Comm FW Version:	56010000
Failure Chain:	

Step	Sequence	Sequence File
Check Outputs	Close command and switches open	FMEA.seq
Close command and switches open	MainSequence	FMEA.seq

**Begin Sequence: MainSequence
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\FMEA.seq)**

Initial state closed	
Status:	Passed
Module Time:	12.6977505

**Begin Sequence: Initial State closed
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\FMEA.seq)**

Read Outputs LOG	
Status:	Done
Output_1_SIG:	True
Output_2_AUX:	False

End Sequence: Initial State closed

Close command and Switch1 closed - Switch2 open	
Status:	Passed
Module Time:	14.3559183

**Begin Sequence: Close command and Switch1 closed - Switch2 open
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\FMEA.seq)**

Read Outputs LOG	
Status:	Done
Output_1_SIG:	True
Output_2_AUX:	False

End Sequence: Close command and Switch1 closed - Switch2 open

Open command and Switch1 open - Switch2 closed	
Status:	Passed
Module Time:	14.4780195

Begin Sequence: Open command and Switch1 open - Switch2 closed
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\FMEA.seq)

Read Outputs LOG	
Status:	Done
Output_1_SIG:	True
Output_2_AUX:	False

End Sequence: Open command and Switch1 open - Switch2 closed

Close command and switches open	
Status:	Failed
Module Time:	15.7175444

Begin Sequence: Close command and switches open
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\FMEA.seq)

Check Outputs	
Status:	Failed
Configuration:	Close command and failure switch 1
Output 1:	True
Output 2:	False

Additional Results	
Status:	Done
Configuration:	How is the status of LED?
Fix_Green:	FIX GREEN

Additional Results	
Status:	Done
Configuration:	How is the status of LED?
locked_MDP:	LOCKED

End Sequence: Close command and switches open

Initial state open	
Status:	Passed
Module Time:	13.114476

Begin Sequence: Initial State open
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\FMEA.seq)

Read Outputs LOG	
Status:	Done
Output_1_SIG:	True
Output_2_AUX:	False

End Sequence: Initial State open

Close command and switches closed	
Status:	Passed
Module Time:	14.9948621

Begin Sequence: Close command and switches closed
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\FMEA.seq)

Check Outputs	
Status:	Passed
Configuration:	Close command and failure switch 2
Output 1:	False
Output 2:	False

Additional Results	
Status:	Done
Configuration:	How is the status of LED?
Blinking_green:	BLINKING GREEN

Additional Results	
Status:	Done
Configuration:	How is the status of LED?
locked_MDP:	LOCKED

End Sequence: Close command and switches closed

Initial state open	
Status:	Passed
Module Time:	12.1110045

Begin Sequence: Initial State open
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\FMEA.seq)

Read Outputs LOG	
Status:	Done
Output_1_SIG:	True
Output_2_AUX:	False

End Sequence: Initial State open

Open command and switches closed	
Status:	Passed
Module Time:	83.7496473

Begin Sequence: Open command and switches closed
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\FMEA.seq)

Check Outputs	
Status:	Passed
Configuration:	Open command and failure switch 1
Output 1:	False
Output 2:	False

Additional Results	
Status:	Done
Configuration:	How is the status of LED?
Blinking_green:	BLINKING GREEN

Additional Results	
Status:	Done
Configuration:	How is the status of LED?
unlocked_MDP:	UNLOCKED

End Sequence: Open command and switches closed

Open command and switches open	
Status:	Failed
Module Time:	8.45615

Begin Sequence: Open command and switches open
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\FMEA.seq)

Check Outputs	
Status:	Failed
Configuration:	Open command and failure switch 2
Output 1:	True
Output 2:	False

Additional Results	
Status:	Done
Configuration:	How is the status of LED?
Blinking_green:	BLINKING GREEN

Additional Results	
Status:	Done
Configuration:	How is the status of LED?
unlocked_MDP:	UNLOCKED

End Sequence: Open command and switches open

Initial state closed	
Status:	Passed
Module Time:	11.3097068

Begin Sequence: Initial State closed
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\FMEA.seq)

Read Outputs LOG	
Status:	Done
Output_1_SIG:	True
Output_2_AUX:	False

End Sequence: Initial State closed

TRIP true	
Status:	Failed
Module Time:	14.1648171

Begin Sequence: TRIP true
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\FMEA.seq)

Check Outputs	
Status:	Failed
Configuration:	TRIP true
Output 1:	True
Output 2:	False

End Sequence: TRIP true

TRIP both switches open	
Status:	Passed
Module Time:	11.0530809

Begin Sequence: TRIP both switches open
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\FMEA.seq)

Check Outputs	
Status:	Passed
Configuration:	TRIP both switches open
Output 1:	False
Output 2:	False
Initial state open	
Status:	Skipped

End Sequence: TRIP both switches open

TRIP both switches closed	
Status:	Passed
Module Time:	10.3680073

Begin Sequence: TRIP both switches closed
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\FMEA.seq)

Check Outputs	
Status:	Passed
Configuration:	TRIP true
Output 1:	False
Output 2:	False

End Sequence: TRIP both switches closed

TRIP - Switch1 open - Switch2 closed	
Status:	Passed
Module Time:	12.5854752

Begin Sequence: TRIP - Switch1 open - Switch2 closed
(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD_Shared\TestStand\Sequences\MOD\FMEA.seq)

Check Outputs	

Status:	Passed
Configuration:	TRIP true
Output 1:	False
Output 2:	False

End Sequence: TRIP - Switch1 open - Switch2 closed

End Sequence: MainSequence

End UUT Report