

UUT Report

Station ID: IT-W-7303101
Serial Number: NONE
Date: venerdì 3 febbraio 2023
Time: 15:27:38
Operator: ITLAVIT1
Execution Time: 00:01:29.166
Number of Results: 397
UUT Result: Passed

Begin Sequence: MainSequence
(C:\Users\itlavit1\OneDrive - ABB\LabRnD_Shared\TestStand\Sequences\Modbus\D13\D13 - Omicron - Modbus RTU settings.seq)

| DUT recap | |
|-------------------|------------|
| Status: | Done |
| TestResults/Data: | |
| Serial Number: | " |
| Type Designator: | B3D4MA111A |
| FW Version: | 0.12.1 |

| Pass/Fail Test | |
|-------------------|--------|
| Status: | Passed |
| TestResults/Data: | |
| Address: | 1 |
| Pass/Fail Test | |
| Status: | Passed |
| TestResults/Data: | |
| Address: | 2 |
| Pass/Fail Test | |
| Status: | Passed |
| TestResults/Data: | |
| Address: | 3 |
| Pass/Fail Test | |
| Status: | Passed |
| TestResults/Data: | |
| Address: | 4 |
| Pass/Fail Test | |
| Status: | Passed |
| TestResults/Data: | |
| Address: | 5 |
| Pass/Fail Test | |
| Status: | Passed |
| TestResults/Data: | |
| Baud Rate: | 9600 |
| Parity: | Even |
| | |

| | |
|-------------------|--------|
| Pass/Fail Test | |
| Status: | Passed |
| TestResults/Data: | |
| Baud Rate: | 9600 |
| Parity: | None |
| Pass/Fail Test | |
| Status: | Passed |
| TestResults/Data: | |
| Baud Rate: | 9600 |
| Parity: | Odd |
| Pass/Fail Test | |
| Status: | Passed |
| TestResults/Data: | |
| Baud Rate: | 19200 |
| Parity: | Even |
| Pass/Fail Test | |
| Status: | Passed |
| TestResults/Data: | |
| Baud Rate: | 19200 |
| Parity: | None |
| Pass/Fail Test | |
| Status: | Passed |
| TestResults/Data: | |
| Baud Rate: | 19200 |
| Parity: | Odd |
| Pass/Fail Test | |
| Status: | Passed |
| TestResults/Data: | |
| Baud Rate: | 38400 |
| Parity: | Even |
| Pass/Fail Test | |
| Status: | Passed |
| TestResults/Data: | |
| Baud Rate: | 38400 |
| Parity: | None |
| Pass/Fail Test | |
| Status: | Passed |
| TestResults/Data: | |
| Baud Rate: | 38400 |
| Parity: | Odd |
| Pass/Fail Test | |
| Status: | Passed |
| TestResults/Data: | |
| Baud Rate: | 57600 |
| Parity: | Even |
| Pass/Fail Test | |
| Status: | Passed |
| TestResults/Data: | |
| Baud Rate: | 57600 |

| | |
|-------------------|--------|
| Parity: | None |
| Pass/Fail Test | |
| Status: | Passed |
| TestResults/Data: | |
| Baud Rate: | 57600 |
| Parity: | Odd |
| Pass/Fail Test | |
| Status: | Passed |
| TestResults/Data: | |
| Baud Rate: | 115200 |
| Parity: | Even |
| Pass/Fail Test | |
| Status: | Passed |
| TestResults/Data: | |
| Baud Rate: | 115200 |
| Parity: | None |
| Pass/Fail Test | |
| Status: | Passed |
| TestResults/Data: | |
| Baud Rate: | 115200 |
| Parity: | Odd |

End Sequence: MainSequence

End UUT Report
