

## UUT Report

**Station ID:** IT-W-7303101  
**Serial Number:** NONE  
**Date:** martedì 10 ottobre 2023  
**Time:** 15:33:18  
**Operator:** administrator  
**Execution Time:** 33.8437235 seconds  
**Number of Results:** 27  
**UUT Result:** **Failed**  
**Product:** ARI LV  
**Product type:** ARI LV  
**Comm type:** COMM1\_RS485  
**Product FW Version:** 56010804  
**Comm FW Version:** 56010000  
**Failure Chain:**

Step	Sequence	Sequence File
<a href="#">Check Lock</a>	MainSequence	Blocked MOD.seq

---

**Begin Sequence: MainSequence**

(C:\Users\ITLUBAR5\ABB\LABRND VITTUONE - LabRnD\_Shared\TestStand\Sequences\MOD\Blocked MOD.seq)

Check Lock	
Status:	Failed
Additional Results	
Status:	Done
PopupString:	Check that ARI reach Lock state after the default number of reclosing attempts.
Status:	Failed
Additional Results	
Status:	Skipped

**End Sequence: MainSequence**

## End UUT Report

---