Test Software P/N 4102483

Tested Part Number 1040000

Test Software Name Trilogy FSA (REPAIR TEST)



Software Revision 24.0.0.0

Prepared By P. Pascal

Test Report

Step	Description	Units	Limits	Results	Pass Fail
36	0021.0570 02 Positive Flow Cal: dP1 at 64,2 (SP 65 @73,1P:	ADC Cnts	LE 1889	1741	√
37	0021.0580 O2 Positive Flow Cal: dPl at 74,0 (SP 75 @71,9P:	ADC Cnts	LE 2023	1890	√
38	0021.0590 O2 Positive Flow Cal: dP1 at 83,8 (SP 85 @70,5P:	ADC Cnts	LE 2154	2024	√
39	0021.0600 O2 Positive Flow Cal: dPl at 93,8 (SP 95 @68,9P;	ADC Cnts	LE 2272	2155	√
40	0021.0610 02 Positive Flow Cal: dPl at 105,0 (SP 105 @67,	ADC Cnts	LE 2375	2272	✓
41	0021.0620 02 Positive Flow Cal: dP1 at 114,0 (SP 115 @65,	ADC Cnts	LE 2490	2376	√
42	0021.0630 02 Positive Flow Cal: dP1 at 125,3 (SP 125 @63,	ADC Cnts	LE 2581	2491	√
43	0021.0640 02 Positive Flow Cal: dP1 at 133,8 (SP 135 @61,	ADC Cnts	LE 2686	2582	√
44	0021.0650 02 Positive Flow Cal: dPl at 144,3 (SP 145 @59,	ADC Cnts	LE 2947	2687	√
45	0021.0660 02 Positive Flow Cal: dPl at 174,3 (SP 175 @55,	ADC Cnts	LE 3089	2948	√
46	0021.0670 O2 Positive Flow Cal: dP1 at 189,3 (SP 190 @53,	ADC Cnts	LE 3999	3090	✓
47	0021.0880 02 Sensor Cal (NO_O2_ERROR): 604 mV at ambient;	N/A	Pass	TRUE	√
48	0021.0930 Write OBM Sensors Cal Table (V: TRUE, A: TRUE)	N/A	Pass	TRUE	√

Test Started On 06/05/24 11:55:53

Serial Number TV010110110 Elapsed Test Time 18m 25s

Status PASS

Page 2 **of** 2