

Test Report

Step	Description	Units	Limits	Results	Pass	Fail
36	0030.0280 Pos Flow Verify: dP2 at 48,0 (Setpoint 50) [11m	SLPM	42,6 to 53,4	54,2		✗
37	0030.0290 Pos Flow Verify: dP2 at 37,7 (Setpoint 40) [11m	SLPM	32,7 to 42,7	42,6	✓	
38	0030.0300 Pos Flow Verify: dP2 at 27,3 (Setpoint 30) [11m	SLPM	22,7 to 31,9	31,4	✓	
39	0030.0310 Pos Flow Verify: dP2 at 20,0 (Setpoint 20) [11m	SLPM	15,0 to 25,0	21,9	✓	
40	0030.0320 Pos Flow Verify: dP2 at 10,0 (Setpoint 10) [11m	SLPM	5,5 to 14,5	10,8	✓	
41	0030.0330 Pos Flow Verify: dP2 at 5,0 (Setpoint 5) [11m 4	SLPM	1,2 to 8,8	5,5	✓	
42	0030.0510 Zero Flow Verify: dP2 at 0,0 (Setpoint 0) [11m	SLPM	-2,0 to 2,0	0,4	✓	
43	0030.0550 Neg Flow Verify: dP2 at -138,5 (Setpoint 140) [SLPM	-147,5 to -129,5	-124,4		✗
44	0030.0560 Neg Flow Verify: dP2 at -128,0 (Setpoint 130) [SLPM	-136,6 to -119,4	-115,9		✗
45	0030.0570 Neg Flow Verify: dP2 at -118,0 (Setpoint 120) [SLPM	-126,2 to -109,8	-107,6		✗
46	0030.0580 Neg Flow Verify: dP2 at -108,2 (Setpoint 110) [SLPM	-116,0 to -100,3	-98,8		✗
47	0030.0590 Neg Flow Verify: dP2 at -98,2 (Setpoint 100) [1	SLPM	-105,6 to -90,7	-89,6		✗
48	0030.0600 Neg Flow Verify: dP2 at -88,7 (Setpoint 90) [18	SLPM	-95,7 to -81,6	-80,0		✗
49	0030.0610 Neg Flow Verify: dP2 at -77,5 (Setpoint 80) [18	SLPM	-84,1 to -70,9	-70,7		✗
50	0030.0620 Neg Flow Verify: dP2 at -67,8 (Setpoint 70) [18	SLPM	-74,0 to -61,6	-63,3	✓	
51	0030.0630 Neg Flow Verify: dP2 at -57,7 (Setpoint 60) [18	SLPM	-63,5 to -51,9	-53,9	✓	
52	0030.0640 Neg Flow Verify: dP2 at -48,0 (Setpoint 50) [18	SLPM	-53,4 to -42,6	-45,3	✓	
53	0030.0650 Neg Flow Verify: dP2 at -38,0 (Setpoint 40) [18	SLPM	-43,0 to -33,0	-36,5	✓	
54	0030.0660 Neg Flow Verify: dP2 at -28,0 (Setpoint 30) [18	SLPM	-32,6 to -23,4	-27,8	✓	
55	0030.0670 Neg Flow Verify: dP2 at -20,0 (Setpoint 20) [18	SLPM	-25,0 to -15,0	-20,0	✓	
56	0030.0680 Neg Flow Verify: dP2 at -10,0 (Setpoint 10) [18	SLPM	-14,5 to -5,5	-9,4	✓	
57	0030.0690 Neg Flow Verify: dP2 at -5,0 (Setpoint 5) [18m	SLPM	-8,8 to -1,2	-4,6	✓	
58	0030.0700 Neg Flow Verify: dP2 at -0,0 (Setpoint 0) [18m	SLPM	-2,0 to 2,0	0,4	✓	
59	0030.0950 Contr.Press.Ver.(8869): P1 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,08	✓	
60	0030.0960 Monit.Press.Ver.(3465): P2 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,13	✓	
61	0030.0160 Pprox Press. Ver.(9079): P2 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,09	✓	
62	0030.0970 Contr.Press.Ver.(11232): P1 at 3,92 (SP 4, 1, 1)	cmH2O	2,92 to 4,92	3,99	✓	
63	0030.0980 Monit.Press.Ver.(6207): P2 at 3,92 (SP 4, 1, 1)	cmH2O	2,92 to 4,92	4,03	✓	
64	0030.0161 Pprox Press. Ver.(11471): P2 at 3,92 (SP 4, 1,	cmH2O	2,92 to 4,92	4,05	✓	
65	0030.0990 Contr.Press.Ver.(19669): P1 at 18,03 (SP 18, 1,	cmH2O	17,03 to 19,03	18,00	✓	
66	0030.1000 Monit.Press.Ver.(16066): P2 at 18,03 (SP 18, 1,	cmH2O	17,03 to 19,03	18,10	✓	
67	0030.0162 Pprox Press. Ver.(19977): P2 at 18,03 (SP 18, 1	cmH2O	17,03 to 19,03	18,16	✓	
68	0030.1010 Contr.Press.Ver.(28108): P1 at 32,03 (SP 32, 1,	cmH2O	31,03 to 33,03	31,99	✓	
69	0030.1020 Monit.Press.Ver.(25886): P2 at 32,03 (SP 32, 1,	cmH2O	31,03 to 33,03	32,09	✓	
70	0030.0163 Pprox Press. Ver.(28466): P2 at 32,03 (SP 32, 1	cmH2O	31,03 to 33,03	32,20	✓	

Test Started On 01/08/24 02:43:36Serial Number TV110052651Elapsed Test Time 23m 26sStatus **TERMINATED**

Page 2 of 3

Audit Info Printed to:doPDF v7 from RESPIRONICS-PC in Production mode.
 File: C:\Program Files\Trilogy Service Cal And Test\Trilogy Repair_PM Cal And Test.exe, Size: 8674304, 05/09/23 10:38
 Station Cfg CRC: 5219, 09/01/21 01:39, Test Cfg CRC: 94CF, 09/01/21 01:39, Models Cfg CRC: 1FF8, 05/05/23 08:20