

Test Software P/N 4102483Tested Part Number 1040000Test Software Name Trilogy FSA (REPAIR TEST)Software Revision 24.0.0.0Prepared By P. Pascal

Test Report

Step	Description	Units	Limits	Results	Pass	Fail
1	0021.0007 OBM O2 Sensor Heater On (NO_O2_ERROR) [0s]	N/A	Pass	TRUE	✓	
2	0021.0010 O2 Press Sensor Cal P1@ 25,15 & 75,25 PSI: Slope	ADC Cnts	0,03010 to 0,0510	0,03330	✓	
3	0021.0020 O2 Press Sensor Cal P1@ 25,15 & 75,25 PSI: Inter	PSI	-25,00 to -10,00	-13,29	✓	
4	0021.0030 O2 Press Sensor Cal P1@ 25,15 & 75,25 PSI: Zero	ADC Cnts	320 to 490	410	✓	
5	0021.0120 Neg Flow Cal: dP2 at -48,3 (Setpoint 45) [4m 46s]	ADC Cnts	GE 101	121	✓	
6	0021.0130 Neg Flow Cal: dP2 at -32,5 (Setpoint 35) [4m 46s]	ADC Cnts	GE 122	363	✓	
7	0021.0140 Neg Flow Cal: dP2 at -23,0 (Setpoint 25) [4m 46s]	ADC Cnts	GE 364	530	✓	
8	0021.0150 Neg Flow Cal: dP2 at -15,0 (Setpoint 15) [4m 46s]	ADC Cnts	GE 531	716	✓	
9	0021.0160 Neg Flow Cal: dP2 at -5,0 (Setpoint 5) [4m 46s]	ADC Cnts	GE 717	1034	✓	
10	0021.0170 Neg Flow Cal: dP2 at -0,0 (Setpoint 0) [4m 46s]	ADC Cnts	GE 1035	1180	✓	
11	0021.0250 Raw Zero Flow: dP2 at 0,0 (Setpoint 0) [4m 46s]	ADC Cnts	GE 0	1180	✓	
12	0021.0300 Pos Flow Cal: dP2 at 5,0 (Setpoint 5) [9m 4s]	ADC Cnts	LE 1633	1326	✓	
13	0021.0310 Pos Flow Cal: dP2 at 14,3 (Setpoint 15) [9m 4s]	ADC Cnts	LE 1857	1634	✓	
14	0021.0320 Pos Flow Cal: dP2 at 25,3 (Setpoint 25) [9m 4s]	ADC Cnts	LE 2057	1858	✓	
15	0021.0330 Pos Flow Cal: dP2 at 38,0 (Setpoint 35) [9m 4s]	ADC Cnts	LE 2195	2058	✓	
16	0021.0340 Pos Flow Cal: dP2 at 47,0 (Setpoint 45) [9m 4s]	ADC Cnts	LE 2328	2196	✓	
17	0021.0350 Pos Flow Cal: dP2 at 57,0 (Setpoint 55) [9m 4s]	ADC Cnts	LE 2458	2328	✓	
18	0021.0360 Pos Flow Cal: dP2 at 67,8 (Setpoint 65) [9m 4s]	ADC Cnts	LE 2573	2459	✓	
19	0021.0370 Pos Flow Cal: dP2 at 77,0 (Setpoint 75) [9m 4s]	ADC Cnts	LE 2677	2574	✓	
20	0021.0380 Pos Flow Cal: dP2 at 87,2 (Setpoint 85) [9m 4s]	ADC Cnts	LE 2782	2678	✓	
21	0021.0390 Pos Flow Cal: dP2 at 97,2 (Setpoint 95) [9m 4s]	ADC Cnts	LE 2875	2783	✓	
22	0021.0400 Pos Flow Cal: dP2 at 106,8 (Setpoint 105) [9m 4s]	ADC Cnts	LE 2953	2876	✓	
23	0021.0410 Pos Flow Cal: dP2 at 117,2 (Setpoint 115) [9m 4s]	ADC Cnts	LE 3033	2954	✓	
24	0021.0420 Pos Flow Cal: dP2 at 127,7 (Setpoint 125) [9m 4s]	ADC Cnts	LE 3106	3034	✓	
25	0021.0430 Pos Flow Cal: dP2 at 137,0 (Setpoint 135) [9m 4s]	ADC Cnts	LE 3149	3107	✓	
26	0021.0440 Pos Flow Cal: dP2 at 144,0 (Setpoint 145) [9m 4s]	ADC Cnts	LE 3336	3150	✓	
27	0021.0450 Pos Flow Cal: dP2 at 172,2 (Setpoint 175) [9m 4s]	ADC Cnts	LE 3437	3337	✓	
28	0021.0460 Pos Flow Cal: dP2 at 188,2 (Setpoint 190) [9m 4s]	ADC Cnts	LE 3999	3438	✓	
29	0021.0500 O2 Positive Flow Cal: dP1 at 0,0 (SP 0 @79,9PSI)	ADC Cnts	LE 403	235	✓	
30	0021.0510 O2 Positive Flow Cal: dP1 at 4,0 (SP 5 @84,0PSI)	ADC Cnts	LE 813	404	✓	
31	0021.0520 O2 Positive Flow Cal: dP1 at 15,0 (SP 15 @83,6PSI)	ADC Cnts	LE 1046	814	✓	
32	0021.0530 O2 Positive Flow Cal: dP1 at 24,7 (SP 25 @83,2PSI)	ADC Cnts	LE 1251	1047	✓	
33	0021.0540 O2 Positive Flow Cal: dP1 at 34,3 (SP 35 @82,9PSI)	ADC Cnts	LE 1420	1252	✓	
34	0021.0550 O2 Positive Flow Cal: dP1 at 44,0 (SP 45 @82,5PSI)	ADC Cnts	LE 1590	1421	✓	
35	0021.0560 O2 Positive Flow Cal: dP1 at 54,0 (SP 55 @82,1PSI)	ADC Cnts	LE 1744	1591	✓	

Test Started On 03/06/24 03:31:27Serial Number TV017111508Elapsed Test Time 16m 35sStatus **PASS**

Page 1 of 2

Audit Info Printed to:doPDF v7 from RESPIRONICS-PC in Troubleshooting: Group Level mode.
File: C:\Program Files\Trilogy Service Cal And Test\Trilogy Repair_PM Cal And Test.exe, Size: 8674304, 05/09/23 10:38
Station Cfg CRC: 5219, 09/01/21 01:39, Test Cfg CRC: 77D6, 09/01/21 01:39, Models Cfg CRC: 2F86, 05/05/23 08:20