

Test Report

Step	Description	Units	Limits	Results	Pass	Fail
36	0030.0280 Pos Flow Verify: dP2 at 48,0 (Setpoint 50) [8m	SLPM	42,6 to 53,4	47,0	✓	
37	0030.0290 Pos Flow Verify: dP2 at 37,5 (Setpoint 40) [8m	SLPM	32,5 to 42,5	37,2	✓	
38	0030.0300 Pos Flow Verify: dP2 at 28,0 (Setpoint 30) [8m	SLPM	23,4 to 32,6	27,9	✓	
39	0030.0310 Pos Flow Verify: dP2 at 19,8 (Setpoint 20) [8m	SLPM	14,8 to 24,8	19,7	✓	
40	0030.0320 Pos Flow Verify: dP2 at 9,8 (Setpoint 10) [8m 4	SLPM	5,3 to 14,3	10,0	✓	
41	0030.0330 Pos Flow Verify: dP2 at 5,0 (Setpoint 5) [8m 43	SLPM	1,2 to 8,8	4,9	✓	
42	0030.0510 Zero Flow Verify: dP2 at 0,0 (Setpoint 0) [8m 5	SLPM	-2,0 to 2,0	0,0	✓	
43	0030.0550 Neg Flow Verify: dP2 at -139,0 (Setpoint 140) [SLPM	-148,1 to -129,9	-144,8	✓	
44	0030.0560 Neg Flow Verify: dP2 at -128,0 (Setpoint 130) [SLPM	-136,6 to -119,4	-132,8	✓	
45	0030.0570 Neg Flow Verify: dP2 at -118,3 (Setpoint 120) [SLPM	-126,6 to -110,1	-123,2	✓	
46	0030.0580 Neg Flow Verify: dP2 at -108,3 (Setpoint 110) [SLPM	-116,2 to -100,5	-112,8	✓	
47	0030.0590 Neg Flow Verify: dP2 at -98,7 (Setpoint 100) [1	SLPM	-106,1 to -91,2	-101,8	✓	
48	0030.0600 Neg Flow Verify: dP2 at -88,5 (Setpoint 90) [12	SLPM	-95,5 to -81,5	-91,5	✓	
49	0030.0610 Neg Flow Verify: dP2 at -78,0 (Setpoint 80) [12	SLPM	-84,6 to -71,4	-80,8	✓	
50	0030.0620 Neg Flow Verify: dP2 at -67,7 (Setpoint 70) [12	SLPM	-73,9 to -61,5	-70,6	✓	
51	0030.0630 Neg Flow Verify: dP2 at -58,0 (Setpoint 60) [12	SLPM	-63,8 to -52,2	-61,3	✓	
52	0030.0640 Neg Flow Verify: dP2 at -48,0 (Setpoint 50) [12	SLPM	-53,4 to -42,6	-49,9	✓	
53	0030.0650 Neg Flow Verify: dP2 at -38,0 (Setpoint 40) [12	SLPM	-43,0 to -33,0	-39,6	✓	
54	0030.0660 Neg Flow Verify: dP2 at -28,0 (Setpoint 30) [12	SLPM	-32,6 to -23,4	-29,3	✓	
55	0030.0670 Neg Flow Verify: dP2 at -19,8 (Setpoint 20) [12	SLPM	-24,8 to -14,8	-20,7	✓	
56	0030.0680 Neg Flow Verify: dP2 at -9,3 (Setpoint 10) [12m	SLPM	-13,8 to -4,8	-10,9	✓	
57	0030.0690 Neg Flow Verify: dP2 at -5,0 (Setpoint 5) [12m	SLPM	-8,8 to -1,2	-5,6	✓	
58	0030.0700 Neg Flow Verify: dP2 at -0,0 (Setpoint 0) [12m	SLPM	-2,0 to 2,0	0,0	✓	
59	0030.0950 Contr.Press.Ver.(8712): P1 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,00	✓	
60	0030.0960 Monit.Press.Ver.(2368): P2 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,34	✓	
61	0030.0160 Pprox Press. Ver.(9318): P2 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,00	✓	
62	0030.0970 Contr.Press.Ver.(11217): P1 at 4,03 (SP 4, 1, 1)	cmH2O	3,03 to 5,03	3,99	✓	
63	0030.0980 Monit.Press.Ver.(4943): P2 at 4,03 (SP 4, 1, 1)	cmH2O	3,03 to 5,03	4,05	✓	
64	0030.0161 Pprox Press. Ver.(11804): P2 at 4,03 (SP 4, 1,	cmH2O	3,03 to 5,03	4,02	✓	
65	0030.0990 Contr.Press.Ver.(19644): P1 at 18,07 (SP 18, 1,	cmH2O	17,07 to 19,07	17,99	✓	
66	0030.1000 Monit.Press.Ver.(14685): P2 at 18,07 (SP 18, 1,	cmH2O	17,07 to 19,07	18,05	✓	
67	0030.0162 Pprox Press. Ver.(20225): P2 at 18,07 (SP 18, 1	cmH2O	17,07 to 19,07	18,01	✓	
68	0030.1010 Contr.Press.Ver.(28075): P1 at 32,04 (SP 32, 1,	cmH2O	31,04 to 33,04	32,00	✓	
69	0030.1020 Monit.Press.Ver.(24393): P2 at 32,04 (SP 32, 1,	cmH2O	31,04 to 33,04	32,03	✓	
70	0030.0163 Pprox Press. Ver.(28661): P2 at 32,04 (SP 32, 1	cmH2O	31,04 to 33,04	32,00	✓	

Test Started On 04/03/24 01:49:07Serial Number TV113102307Elapsed Test Time 32m 6sStatus **FAIL**

Page 2 of 5

Audit Info Printed to:doPDF v7 from RESPIRONICS-PC in Production mode.

File: C:\Program Files\Trilogy Service Cal And Test\Trilogy Repair_PM Cal And Test.exe, Size: 8674304, 05/09/23 10:38
Station Cfg CRC: 5219, 09/01/21 01:39, Test Cfg CRC: 94CF, 09/01/21 01:39, Models Cfg CRC: 2F86, 05/05/23 08:20