ANDOVER 12-02-2024

Fluke Biomedical Ansur Test and Inspection Procedure

Copyright © 2000 - 2014 Fluke Biomedical

Test Record

TEST PASSED

Test Performed Ansur Components Used

 Date:
 12-02-2024

 Record:
 IEC 60601-1 - CL2.mtr

 Template:
 IEC 60601-1 - CL2.mtt

Ansur Version 3.1.4 Plug-In: ESA612 Version 1.1.3

Test Setup

Selections

Service Events Performed	Standards Performed
	IFC 60601

Device under test

Serial Number	TV014061613	Туре	Ventilador
Appliance Code		Model	Trilogy 202
Group		Location	Andover
Status		Address 1	Enea
Manufacturer	Respironics	Address 2	Laboratorio

MTI Data

Test Instrument Serial Number		Firmware Version	
ESA612B	6034120	v3.01	

Signatures

IEC 60601-1 - CL2.mtr Page 1 of 2

Test Result

Test Element		Test Ty				Fail
IEC 60601-1 - CL2		Auto Se	quence			
Procedure: (1) Connect the DLIT to the ESA(12 or indicated in the energters manual						
(1) Connect the DUT to the ESA612 as indicated in the operators manual.						
(2) Ensure that DUT power is On.(3) Click module setup and specify the patient leads that are to be tested.						
				nat are to be tes	tea.	
(4) Connect patient lea						
(5) Click Start Test to	perform ti	ne safety	test.			
Configuration:						
Polarity Switching Delay:3(s)						
Mains Voltage		Mains V	oltage			
Live to Neutral		Mains V				
Result:	Value	Live to l Unit	veutrai High Limit	Low Limit	Standard	
Live to Neutral	235,0	\ \	riigii Liiiii	LOW LITTIE	IEC 60601	
Enclosure Leakage Current		Enclosure Leakage Current				
Configuration:			Ü			
Unused Applied						
Parts:Floating						
Normal Condition		Enclosure Leakage Current Normal Condition				
Result:	Value	Norman Unit	High Limit	Low Limit	Standard	
Normal Condition	0,6	uA	100	2011 2	IEC 60601	
Open Neutral		Enclosu	re Leakage Cur	rent		
Open Neutral		Open N				
Result: Open Neutral	Value 0,8	Unit uA	High Limit 500	Low Limit	Standard IEC 60601	
Open Neutral	0,0	uA	500		ILC 00001	
		Enclosu	re Leakage Cur	rent		
Normal Condition, Reversed mains		Normal	Condition, Reve	ersed mains		
Result:	Value	Unit	High Limit	Low Limit	Standard	
Normal Condition, Reversed mains	0,6	uA	100		IEC 60601	
neverseu mains						
On an Neutral Deversed Mair-		Enclosu	re Leakage Cur	rent		
Open Neutral, Reversed Mains		Open Neutral, Reversed Mains				
Result:	Value	Unit	High Limit	Low Limit	Standard	
Open Neutral, Reversed Mains	0,9	uA	500		IEC 60601	
Meverseu ividiris						

IEC 60601-1 - CL2.mtr Page 2 of 2