

Test Software P/N 4102483Tested Part Number LA1054096Test Software Name Trilogy FSA (REPAIR TEST)Software Revision 24.0.0.0Prepared By P. Pascal

Test Report

Step	Description	Units	Limits	Results	Pass	Fail
1	0020.0001 Ambient Air: RH=46,40%; T=22,70Cdeg [14s]	N/A	Pass	TRUE	✓	
2	0020.0010 O2 Sensor Heater On (not attempted for SW ver.1.1)	N/A	None	None	✓	
3	0020.0010 Press Sensors Cal P1@4,04&50,01cmH2O/9603&32952	20/ADC C	0,00151 to 0,0018	0,00166	✓	
4	0020.0020 Press Sensors Cal P1@4,04&50,01cmH2O/9603&32952	cmH2O	-18,22 to -9,05	-13,24	✓	
5	0020.0030 Press Sensors Cal P1@4,04&50,01cmH2O/9603&32952	ADC Cnts	5994 to 9998	7982	✓	
6	0020.0040 Press Sensors Cal P2@4,04&50,01cmH2O/9603&32952	20/ADC C	0,00114 to 0,0018	0,00144	✓	
7	0020.0050 Press Sensors Cal P2@4,04&50,01cmH2O/9603&32952	cmH2O	-19,53 to 0,00	-5,84	✓	
8	0020.0060 Press Sensors Cal P2@4,04&50,01cmH2O/9603&32952	ADC Cnts	0 to 10399	4075	✓	
9	0020.0950 Press Sensors Cal Pprox@4,04&50,01cmH2O/9603&32	20/ADC C	0,00151 to 0,0018	0,00167	✓	
10	0020.0960 Press Sensors Cal Pprox@4,04&50,01cmH2O/9603&32	cmH2O	-18,22 to -9,05	-13,36	✓	
11	0020.0970 Press Sensors Cal Pprox@4,04&50,01cmH2O/9603&32	ADC Cnts	5994 to 9998	8048	✓	
12	0020.0120 Neg Flow Cal: dP2 at -146,0 (Setpoint 145) [11m	ADC Cnts	GE 101	13867	✓	
13	0020.0130 Neg Flow Cal: dP2 at -132,5 (Setpoint 135) [11m	ADC Cnts	GE 13868	14829	✓	
14	0020.0140 Neg Flow Cal: dP2 at -123,7 (Setpoint 125) [11m	ADC Cnts	GE 14830	15542	✓	
15	0020.0150 Neg Flow Cal: dP2 at -113,2 (Setpoint 115) [11m	ADC Cnts	GE 15543	16419	✓	
16	0020.0160 Neg Flow Cal: dP2 at -103,0 (Setpoint 105) [11m	ADC Cnts	GE 16420	17394	✓	
17	0020.0170 Neg Flow Cal: dP2 at -93,3 (Setpoint 95) [11m 8s]	ADC Cnts	GE 17395	18446	✓	
18	0020.0180 Neg Flow Cal: dP2 at -83,0 (Setpoint 85) [11m 8s]	ADC Cnts	GE 18447	19521	✓	
19	0020.0190 Neg Flow Cal: dP2 at -73,0 (Setpoint 75) [11m 8s]	ADC Cnts	GE 19522	20630	✓	
20	0020.0200 Neg Flow Cal: dP2 at -63,0 (Setpoint 65) [11m 8s]	ADC Cnts	GE 20631	21695	✓	
21	0020.0210 Neg Flow Cal: dP2 at -53,3 (Setpoint 55) [11m 8s]	ADC Cnts	GE 21696	22951	✓	
22	0020.0220 Neg Flow Cal: dP2 at -43,0 (Setpoint 45) [11m 8s]	ADC Cnts	GE 22952	24443	✓	
23	0020.0230 Neg Flow Cal: dP2 at -33,0 (Setpoint 35) [11m 8s]	ADC Cnts	GE 24444	25901	✓	
24	0020.0240 Neg Flow Cal: dP2 at -23,0 (Setpoint 25) [11m 8s]	ADC Cnts	GE 25902	27725	✓	
25	0020.0250 Neg Flow Cal: dP2 at -14,3 (Setpoint 15) [11m 8s]	ADC Cnts	GE 27726	29413	✓	
26	0020.0260 Neg Flow Cal: dP2 at -5,0 (Setpoint 5) [11m 8s]	ADC Cnts	GE 29414	32248	✓	
27	0020.0270 Neg Flow Cal: dP2 at -0,0 (Setpoint 0) [11m 8s]	ADC Cnts	GE 32249	33436	✓	
28	0020.0450 Raw Zero Flow: dP2 at 0,0 (Setpoint 0) [11m 8s]	ADC Cnts	GE 0	33436	✓	
29	0020.0500 Pos Flow Cal: dP2 at 5,0 (Setpoint 5) [16m 16s]	ADC Cnts	LE 37470	34716	✓	
30	0020.0510 Pos Flow Cal: dP2 at 15,0 (Setpoint 15) [16m 16s]	ADC Cnts	LE 39272	37471	✓	
31	0020.0520 Pos Flow Cal: dP2 at 23,7 (Setpoint 25) [16m 16s]	ADC Cnts	LE 40913	39273	✓	
32	0020.0530 Pos Flow Cal: dP2 at 34,0 (Setpoint 35) [16m 16s]	ADC Cnts	LE 42189	40914	✓	
33	0020.0540 Pos Flow Cal: dP2 at 44,0 (Setpoint 45) [16m 16s]	ADC Cnts	LE 43903	42190	✓	
34	0020.0550 Pos Flow Cal: dP2 at 58,0 (Setpoint 55) [16m 16s]	ADC Cnts	LE 44930	43904	✓	
35	0020.0560 Pos Flow Cal: dP2 at 67,0 (Setpoint 65) [16m 16s]	ADC Cnts	LE 46036	44930	✓	

Test Started On 08/29/24 10:35:56Serial Number TV119091018Elapsed Test Time 21m 15sStatus **PASS**

Page 1 of 2

Audit Info Printed to:doPDF v7 from RESPIRONICS-PC in Troubleshooting: Group Level mode.
 File: C:\Program Files\Trilogy Service Cal And Test\Trilogy Repair_PM Cal And Test.exe, Size: 8674304, 05/09/23 10:38
 Station Cfg CRC: 5219, 09/01/21 01:39, Test Cfg CRC: 77D6, 09/01/21 01:39, Models Cfg CRC: 2F86, 05/05/23 08:20