Test Software P/N 4102483

Tested Part Number 1040000

Test Software Name Trilogy FSA (REPAIR TEST)



Software Revision 24.0.0.0

Prepared By P. Pascal

Test Report

Step	Description	Units	Limits	Results	Pass	Fail
36	0021.0570 02 Positive Flow Cal: dP1 at 64,8 (SP 65 @81,5P	ADC Cnts	LE 1844	1707	√	
37	0021.0580 02 Positive Flow Cal: dP1 at 74,2 (SP 75 @81,1P	ADC Cnts	LE 1978	1846	√	
38	0021.0590 O2 Positive Flow Cal: dP1 at 84,5 (SP 85 @80,5P	ADC Cnts	LE 2086	1979	√	
39	0021.0600 O2 Positive Flow Cal: dP1 at 93,7 (SP 95 @79,9P	ADC Cnts	LE 2210	2087	√	
40	0021.0610 02 Positive Flow Cal: dP1 at 104,8 (SP 105 @79,	ADC Cnts	LE 2308	2211	√	
41	0021.0620 02 Positive Flow Cal: dP1 at 114,0 (SP 115 @78,	ADC Cnts	LE 2402	2309	√	
42	0021.0630 O2 Positive Flow Cal: dP1 at 124,5 (SP 125 @77,	ADC Cnts	LE 2504	2403	√	
43	0021.0640 02 Positive Flow Cal: dP1 at 135,0 (SP 135 @76,	ADC Cnts	LE 2605	2505	√	
44	0021.0650 02 Positive Flow Cal: dP1 at 145,0 (SP 145 @75,	ADC Cnts	LE 2870	2606	√	
45	0021.0660 O2 Positive Flow Cal: dP1 at 175,3 (SP 175 @73,	ADC Cnts	LE 2983	2870	√	
46	0021.0670 O2 Positive Flow Cal: dP1 at 190,2 (SP 190 @71,	ADC Cnts	LE 3999	2984	√	
47	0021.0880 02 Sensor Cal (RANGE_FAILURE): 2 mV at ambient	N/A	Pass	FALSE		×
48	0021.0930 Write OBM Sensors Cal Table [52m 54s]	N/A	Pass	FALSE		×
						
		1				
						
						
						-
					\perp	
						<u> </u>
						<u> </u>

Test Started On 02/05/24 12:04:35

Elapsed Test Time 52m 54s

Status FAIL

Serial Number TV014061613

Page 2 **of** 2