ANDOVER 16-08-2024

Fluke Biomedical Ansur Test and Inspection Procedure

Copyright © 2000 - 2014 Fluke Biomedical

Test record

TEST PASSED

Test performed Components used

 Date:
 16-08-2024

 Record:
 IEC 60601-1 - CL2.mtr

 Template:
 IEC 60601-1 - CL2.mtt

Ansur Version 3.1.4 Plug-In: ESA612 Version 1.1.3

Test setup

Selections

Service events performed	Standards performed
	IFC 60601

Device under test

Número de serie	TV018100946	Modelo	Trilogy 202
Estado	Reparado	Localización	Andover Alianza Medica S. A.
Fabricante	Philips Respironics	Dirección 1	Salar De Huasco 795, Pudahuel
Tipo	Ventilador Mecanico No Invasivo	Dirección 2	Laboratorio

MTI Data

Test instrument	Serial number	Firmware version
ESA612B	4465048	v3.00

Signatures

IEC 60601-1 - CL2.mtr Página 1 de 2

Test result

Test element		Test ty	pe		F	ail
IEC 60601-1 - CL2		Auto Se				
Procedure:	2 tha ESA4	12 ac indi	catad in th	o operators man	ual	
(1) Connect the DUT to			cated in the	e operators mani	ual.	
(2) Ensure that DUT po			ont loads t	hat are to be too	tod	
(3) Click module setup and specify the patient leads that are to be tested.(4) Connect patient leads as indicated to the right.						
(5) Click Start Test to						
(5) Chek Start Test to	ренонни	ile salety	test.			
Configuration						
Polarity Switching Delay:3(s)						
Mains Voltage		Mains V	oltage			
Live to Neutral		Mains V				
Result:	Valera	Live to N		l au lim!	Ct	
Live to Neutral	Value 221,4	Unit ∨	High limit	Low limit	Standard IEC 60601	
	,.	•				
Enclosure Leakage Current		Enclosui	re Leakage Curi	rent		
Configuration			· ·			
Unused Applied						
Parts:Floating						
		Enclosu	re Leakage Curi	rent		
Normal Condition			Condition			
Result:	Value	Unit	High limit	Low limit	Standard	
Normal Condition	0,5	uA	100		IEC 60601	
Open Neutral			re Leakage Curi	rent		
Result:	Value	Open Ne Unit	eutral High limit	Low limit	Standard	
Open Neutral	0,6	uA	500	LOW IIIIII	IEC 60601	
	.,.					
Normal Condition, Reversed mains			re Leakage Curi			
Result:	Value	Normal (Unit	Condition, Reve		Standard	
Normal Condition,			High limit	Low limit		
Reversed mains	0,5	uA	100		IEC 60601	
Open Neutral, Reversed Mains			re Leakage Curi			
Result:	Value	Open Ne Unit	eutral, Reversed High limit	l Mains Low limit	Standard	
Open Neutral,		uA	500	2011 111111	IEC 60601	
Reversed Mains	0,6	uА	500		IEC 00001	

IEC 60601-1 - CL2.mtr Página 2 de 2