

# Test Report

Step	Description	Units	Limits	Results	Pass	Fail
36	0030.0280 Pos Flow Verify: dP2 at 47,9 (Setpoint 50) [13m	SLPM	42,4 to 53,3	54,8		✗
37	0030.0290 Pos Flow Verify: dP2 at 37,5 (Setpoint 40) [13m	SLPM	32,5 to 42,5	44,0		✗
38	0030.0300 Pos Flow Verify: dP2 at 28,0 (Setpoint 30) [13m	SLPM	23,4 to 32,6	33,9		✗
39	0030.0310 Pos Flow Verify: dP2 at 20,0 (Setpoint 20) [13m	SLPM	15,0 to 25,0	24,4	✓	
40	0030.0320 Pos Flow Verify: dP2 at 10,0 (Setpoint 10) [13m	SLPM	5,5 to 14,5	13,9	✓	
41	0030.0330 Pos Flow Verify: dP2 at 5,0 (Setpoint 5) [13m 3	SLPM	1,2 to 8,8	8,2	✓	
42	0030.0510 Zero Flow Verify: dP2 at 0,0 (Setpoint 0) [13m	SLPM	-2,0 to 2,0	2,1		✗
43	0030.0550 Neg Flow Verify: dP2 at -138,8 (Setpoint 140) [	SLPM	-147,9 to -129,8	-126,7		✗
44	0030.0560 Neg Flow Verify: dP2 at -128,3 (Setpoint 130) [	SLPM	-137,0 to -119,7	-117,5		✗
45	0030.0570 Neg Flow Verify: dP2 at -117,3 (Setpoint 120) [	SLPM	-125,5 to -109,1	-108,8		✗
46	0030.0580 Neg Flow Verify: dP2 at -108,2 (Setpoint 110) [	SLPM	-116,0 to -100,3	-101,0	✓	
47	0030.0590 Neg Flow Verify: dP2 at -98,3 (Setpoint 100) [2	SLPM	-105,8 to -90,9	-92,4	✓	
48	0030.0600 Neg Flow Verify: dP2 at -88,3 (Setpoint 90) [21	SLPM	-95,3 to -81,3	-82,7	✓	
49	0030.0610 Neg Flow Verify: dP2 at -77,7 (Setpoint 80) [21	SLPM	-84,3 to -71,1	-75,1	✓	
50	0030.0620 Neg Flow Verify: dP2 at -67,8 (Setpoint 70) [21	SLPM	-74,0 to -61,6	-68,3	✓	
51	0030.0630 Neg Flow Verify: dP2 at -58,0 (Setpoint 60) [21	SLPM	-63,8 to -52,2	-60,3	✓	
52	0030.0640 Neg Flow Verify: dP2 at -48,2 (Setpoint 50) [21	SLPM	-53,6 to -42,7	-51,0	✓	
53	0030.0650 Neg Flow Verify: dP2 at -38,0 (Setpoint 40) [21	SLPM	-43,0 to -33,0	-41,4	✓	
54	0030.0660 Neg Flow Verify: dP2 at -28,0 (Setpoint 30) [21	SLPM	-32,6 to -23,4	-30,9	✓	
55	0030.0670 Neg Flow Verify: dP2 at -20,0 (Setpoint 20) [21	SLPM		ERROR 8003		✗
56	0030.0680 Neg Flow Verify: dP2 at -10,0 (Setpoint 10) [21	SLPM	-14,5 to -5,5	-10,8	✓	
57	0030.0690 Neg Flow Verify: dP2 at -4,8 (Setpoint 5) [21m	SLPM	-8,6 to -1,1	-3,9	✓	
58	0030.0700 Neg Flow Verify: dP2 at -0,0 (Setpoint 0) [21m	SLPM	-2,0 to 2,0	2,1		✗
59	0030.0950 Contr.Press.Ver.(8058): P1 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,07	✓	
60	0030.0960 Monit.Press.Ver.(4682): P2 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,00	✓	
61	0030.0160 Pprox Press. Ver.(7818): P2 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,04	✓	
62	0030.0970 Contr.Press.Ver.(10410): P1 at 3,91 (SP 4, 1, 1)	cmH2O	2,91 to 4,91	3,99	✓	
63	0030.0980 Monit.Press.Ver.(7419): P2 at 3,91 (SP 4, 1, 1)	cmH2O	2,91 to 4,91	3,89	✓	
64	0030.0161 Pprox Press. Ver.(10190): P2 at 3,91 (SP 4, 1,	cmH2O	2,91 to 4,91	3,98	✓	
65	0030.0990 Contr.Press.Ver.(18817): P1 at 17,82 (SP 18, 1,	cmH2O	16,82 to 18,82	17,99	✓	
66	0030.1000 Monit.Press.Ver.(17078): P2 at 17,82 (SP 18, 1,	cmH2O	16,82 to 18,82	17,77	✓	
67	0030.0162 Pprox Press. Ver.(18606): P2 at 17,82 (SP 18, 1	cmH2O	16,82 to 18,82	18,02	✓	
68	0030.1010 Contr.Press.Ver.(27223): P1 at 31,76 (SP 32, 1,	cmH2O	30,76 to 32,76	31,99	✓	
69	0030.1020 Monit.Press.Ver.(26778): P2 at 31,76 (SP 32, 1,	cmH2O	30,76 to 32,76	31,70	✓	
70	0030.0163 Pprox Press. Ver.(27000): P2 at 31,76 (SP 32, 1	cmH2O	30,76 to 32,76	31,97	✓	

Test Started On 01/15/24 09:51:07Serial Number TV11412164BElapsed Test Time 27m 50sStatus **ERROR**

Page 2 of 3

Audit Info Printed to:doPDF v7 from RESPIRONICS-PC in Production mode.  
 File: C:\Program Files\Trilogy Service Cal And Test\Trilogy Repair\_PM Cal And Test.exe, Size: 8674304, 05/09/23 10:38  
 Station Cfg CRC: 5219, 09/01/21 01:39, Test Cfg CRC: 94CF, 09/01/21 01:39, Models Cfg CRC: 2F86, 05/05/23 08:20