

Test Report

Step	Description	Units	Limits	Results	Pass	Fail
36	0030.0280 Pos Flow Verify: dP2 at 47,8 (Setpoint 50) [18m	SLPM	42,4 to 53,2	50,5	✓	
37	0030.0290 Pos Flow Verify: dP2 at 37,0 (Setpoint 40) [18m	SLPM	32,0 to 42,0	40,0	✓	
38	0030.0300 Pos Flow Verify: dP2 at 28,0 (Setpoint 30) [18m	SLPM	23,4 to 32,6	30,2	✓	
39	0030.0310 Pos Flow Verify: dP2 at 20,0 (Setpoint 20) [18m	SLPM	15,0 to 25,0	21,1	✓	
40	0030.0320 Pos Flow Verify: dP2 at 9,3 (Setpoint 10) [18m	SLPM	4,8 to 13,8	10,0	✓	
41	0030.0330 Pos Flow Verify: dP2 at 4,7 (Setpoint 5) [18m 9	SLPM	0,9 to 8,4	5,2	✓	
42	0030.0510 Zero Flow Verify: dP2 at 0,0 (Setpoint 0) [18m	SLPM	-2,0 to 2,0	-0,3	✓	
43	0030.0550 Neg Flow Verify: dP2 at -138,3 (Setpoint 140) [SLPM	-147,4 to -129,3	-138,6	✓	
44	0030.0560 Neg Flow Verify: dP2 at -128,0 (Setpoint 130) [SLPM	-136,6 to -119,4	-127,8	✓	
45	0030.0570 Neg Flow Verify: dP2 at -117,8 (Setpoint 120) [SLPM	-126,0 to -109,6	-118,4	✓	
46	0030.0580 Neg Flow Verify: dP2 at -108,0 (Setpoint 110) [SLPM	-115,8 to -100,2	-109,0	✓	
47	0030.0590 Neg Flow Verify: dP2 at -98,7 (Setpoint 100) [2	SLPM	-106,1 to -91,2	-99,6	✓	
48	0030.0600 Neg Flow Verify: dP2 at -88,7 (Setpoint 90) [25	SLPM	-95,7 to -81,6	-88,0	✓	
49	0030.0610 Neg Flow Verify: dP2 at -77,7 (Setpoint 80) [25	SLPM	-84,3 to -71,1	-78,2	✓	
50	0030.0620 Neg Flow Verify: dP2 at -67,5 (Setpoint 70) [25	SLPM	-73,7 to -61,3	-69,6	✓	
51	0030.0630 Neg Flow Verify: dP2 at -58,0 (Setpoint 60) [25	SLPM	-63,8 to -52,2	-61,1	✓	
52	0030.0640 Neg Flow Verify: dP2 at -48,0 (Setpoint 50) [25	SLPM	-53,4 to -42,6	-50,5	✓	
53	0030.0650 Neg Flow Verify: dP2 at -38,0 (Setpoint 40) [25	SLPM	-43,0 to -33,0	-40,2	✓	
54	0030.0660 Neg Flow Verify: dP2 at -28,0 (Setpoint 30) [25	SLPM	-32,6 to -23,4	-30,3	✓	
55	0030.0670 Neg Flow Verify: dP2 at -20,0 (Setpoint 20) [25	SLPM	-25,0 to -15,0	-21,6	✓	
56	0030.0680 Neg Flow Verify: dP2 at -10,0 (Setpoint 10) [25	SLPM	-14,5 to -5,5	-11,4	✓	
57	0030.0690 Neg Flow Verify: dP2 at -5,0 (Setpoint 5) [25m	SLPM	-8,8 to -1,2	-5,9	✓	
58	0030.0700 Neg Flow Verify: dP2 at -0,0 (Setpoint 0) [25m	SLPM	-2,0 to 2,0	-0,3	✓	
59	0030.0950 Contr.Press.Ver.(8755): P1 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	1,16		✗
60	0030.0960 Monit.Press.Ver.(3846): P2 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,24	✓	
61	0030.0160 Pprox Press. Ver.(8936): P2 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,52	✓	
62	0030.0970 Contr.Press.Ver.(10464): P1 at 2,97 (SP 4, 1, 1)	cmH2O	1,97 to 3,97	3,99		✗
63	0030.0980 Monit.Press.Ver.(5806): P2 at 2,97 (SP 4, 1, 1)	cmH2O	1,97 to 3,97	3,06	✓	
64	0030.0161 Pprox Press. Ver.(10624): P2 at 2,97 (SP 4, 1,	cmH2O	1,97 to 3,97	3,31	✓	
65	0030.0990 Contr.Press.Ver.(18890): P1 at 16,96 (SP 18, 1,	cmH2O	15,96 to 17,96	17,99		✗
66	0030.1000 Monit.Press.Ver.(15473): P2 at 16,96 (SP 18, 1,	cmH2O	15,96 to 17,96	17,02	✓	
67	0030.0162 Pprox Press. Ver.(19120): P2 at 16,96 (SP 18, 1	cmH2O	15,96 to 17,96	17,40	✓	
68	0030.1010 Contr.Press.Ver.(27306): P1 at 30,91 (SP 32, 1,	cmH2O	29,91 to 31,91	31,99		✗
69	0030.1020 Monit.Press.Ver.(25139): P2 at 30,91 (SP 32, 1,	cmH2O	29,91 to 31,91	30,96	✓	
70	0030.0163 Pprox Press. Ver.(27513): P2 at 30,91 (SP 32, 1	cmH2O	29,91 to 31,91	31,40	✓	

Test Started On 08/07/24 11:23:11Serial Number TV113031429Elapsed Test Time 29m 46sStatus **FAIL**

Page 2 of 3

Audit Info Printed to:doPDF v7 from RESPIRONICS-PC in Production mode.
 File: C:\Program Files\Trilogy Service Cal And Test\Trilogy Repair_PM Cal And Test.exe, Size: 8674304, 05/09/23 10:38
 Station Cfg CRC: 5219, 09/01/21 01:39, Test Cfg CRC: 94CF, 09/01/21 01:39, Models Cfg CRC: 2F86, 05/05/23 08:20