Test Software P/N 4102483

Tested Part Number 1040000

Test Software Name Trilogy FSA (REPAIR TEST)



Software Revision 24.0.0.0

Prepared By P. Pascal

Test Report

Step	Description	Units	Limits	Results	Pass	Fail
36	0021.0570 02 Positive Flow Cal: dP1 at 65,0 (SP 65 @77,9P	ADC Cnts	LE 1923	1786	√	_
37	0021.0580 02 Positive Flow Cal: dP1 at 74,5 (SP 75 @76,6P	ADC Cnts	LE 2067	1924	√	
38	0021.0590 02 Positive Flow Cal: dP1 at 85,0 (SP 85 @75,1P	ADC Cnts	LE 2191	2068	√	_
39	0021.0600 02 Positive Flow Cal: dP1 at 95,0 (SP 95 @73,7P	ADC Cnts	LE 2298	2192	√	
40	0021.0610 02 Positive Flow Cal: dP1 at 103,8 (SP 105 @72,	\DC Cnts	LE 2399	2299	✓	_
41	0021.0620 02 Positive Flow Cal: dP1 at 113,5 (SP 115 @71,	ADC Cnts	LE 2516	2400	√	
42	0021.0630 02 Positive Flow Cal: dP1 at 125,2 (SP 125 @70,	ADC Cnts	LE 2605	2517	✓	
43	0021.0640 02 Positive Flow Cal: dP1 at 134,8 (SP 135 @69,	ADC Cnts	LE 2702	2606	✓	_
44	0021.0650 02 Positive Flow Cal: dP1 at 145,0 (SP 145 @68,	ADC Cnts	LE 2972	2703	√	-
45	0021.0660 02 Positive Flow Cal: dP1 at 174,8 (SP 175 @64,	ADC Cnts	LE 3105	2974	√	
46	0021.0670 02 Positive Flow Cal: dP1 at 189,7 (SP 190 @62,	ADC Cnts	LE 3999	3106	√	
47	0021.0880 02 Sensor Cal (RANGE_FAILURE): 3 mV at ambient	N/A	Pass	FALSE		<u>×</u>
48	0021.0930 Write OBM Sensors Cal Table [14m 36s]	N/A	Pass	FALSE		<u>×</u>
						_
						—
					-	—
					-	
						—
						—

Test Started On 02/02/24 03:33:24

Serial Number TV014061613 Elapsed Test Time 14m 36s

Page 2 **of** 2