

Test Software P/N 4102483Tested Part Number 1040000Test Software Name Trilogy FSA (REPAIR TEST)Software Revision 24.0.0.0Prepared By P. Pascal

Test Report

Step	Description	Units	Limits	Results	Pass	Fail
1	0021.0007 OBM O2 Sensor Heater On (NO_O2_ERROR) [0s]	N/A	Pass	TRUE	✓	
2	0021.0010 O2 Press Sensor Cal P1@ 25,20 & 75,10 PSI: Slope	ADC Cnts	0,03010 to 0,0510	0,03322	✓	
3	0021.0020 O2 Press Sensor Cal P1@ 25,20 & 75,10 PSI: Inter	PSI	-25,00 to -10,00	-13,14	✓	
4	0021.0030 O2 Press Sensor Cal P1@ 25,20 & 75,10 PSI: Zero	ADC Cnts	320 to 490	409	✓	
5	0021.0120 Neg Flow Cal: dP2 at -47,0 (Setpoint 45) [32m 4	ADC Cnts	GE 101	260	✓	
6	0021.0130 Neg Flow Cal: dP2 at -33,0 (Setpoint 35) [32m 4	ADC Cnts	GE 260	452	✓	
7	0021.0140 Neg Flow Cal: dP2 at -24,0 (Setpoint 25) [32m 4	ADC Cnts	GE 453	613	✓	
8	0021.0150 Neg Flow Cal: dP2 at -15,0 (Setpoint 15) [32m 4	ADC Cnts	GE 614	812	✓	
9	0021.0160 Neg Flow Cal: dP2 at -5,0 (Setpoint 5) [32m 40s	ADC Cnts	GE 813	1043	✓	
10	0021.0170 Neg Flow Cal: dP2 at -0,0 (Setpoint 0) [32m 40s	ADC Cnts	GE 1044	1160	✓	
11	0021.0250 Raw Zero Flow: dP2 at 0,0 (Setpoint 0) [32m 40s	ADC Cnts	GE 0	1160	✓	
12	0021.0300 Pos Flow Cal: dP2 at 5,0 (Setpoint 5) [37m 35s]	ADC Cnts	LE 1688	1444	✓	
13	0021.0310 Pos Flow Cal: dP2 at 14,8 (Setpoint 15) [37m 35	ADC Cnts	LE 1845	1689	✓	
14	0021.0320 Pos Flow Cal: dP2 at 23,0 (Setpoint 25) [37m 35	ADC Cnts	LE 2082	1846	✓	
15	0021.0330 Pos Flow Cal: dP2 at 37,0 (Setpoint 35) [37m 35	ADC Cnts	LE 2228	2083	✓	
16	0021.0340 Pos Flow Cal: dP2 at 46,8 (Setpoint 45) [37m 35	ADC Cnts	LE 2376	2229	✓	
17	0021.0350 Pos Flow Cal: dP2 at 56,2 (Setpoint 55) [37m 35	ADC Cnts	LE 2519	2377	✓	
18	0021.0360 Pos Flow Cal: dP2 at 67,0 (Setpoint 65) [37m 35	ADC Cnts	LE 2625	2520	✓	
19	0021.0370 Pos Flow Cal: dP2 at 75,7 (Setpoint 75) [37m 35	ADC Cnts	LE 2753	2626	✓	
20	0021.0380 Pos Flow Cal: dP2 at 87,5 (Setpoint 85) [37m 35	ADC Cnts	LE 2830	2754	✓	
21	0021.0390 Pos Flow Cal: dP2 at 96,0 (Setpoint 95) [37m 35	ADC Cnts	LE 2943	2831	✓	
22	0021.0400 Pos Flow Cal: dP2 at 107,5 (Setpoint 105) [37m	ADC Cnts	LE 3030	2944	✓	
23	0021.0410 Pos Flow Cal: dP2 at 117,3 (Setpoint 115) [37m	ADC Cnts	LE 3103	3030	✓	
24	0021.0420 Pos Flow Cal: dP2 at 126,8 (Setpoint 125) [37m	ADC Cnts	LE 3185	3104	✓	
25	0021.0430 Pos Flow Cal: dP2 at 137,3 (Setpoint 135) [37m	ADC Cnts	LE 3256	3186	✓	
26	0021.0440 Pos Flow Cal: dP2 at 147,7 (Setpoint 145) [37m	ADC Cnts	LE 3424	3257	✓	
27	0021.0450 Pos Flow Cal: dP2 at 172,8 (Setpoint 175) [37m	ADC Cnts	LE 3518	3425	✓	
28	0021.0460 Pos Flow Cal: dP2 at 189,0 (Setpoint 190) [37m	ADC Cnts	LE 3999	3519	✓	
29	0021.0500 O2 Positive Flow Cal: dP1 at 0,0 (SP 0 @75,1PSI	ADC Cnts	LE 438	238	✓	
30	0021.0510 O2 Positive Flow Cal: dP1 at 4,0 (SP 5 @75,4PSI	ADC Cnts	LE 873	440	✓	
31	0021.0520 O2 Positive Flow Cal: dP1 at 14,8 (SP 15 @74,9P	ADC Cnts	LE 1123	874	✓	
32	0021.0530 O2 Positive Flow Cal: dP1 at 24,7 (SP 25 @74,5P	ADC Cnts	LE 1320	1124	✓	
33	0021.0540 O2 Positive Flow Cal: dP1 at 34,0 (SP 35 @74,1P	ADC Cnts	LE 1500	1321	✓	
34	0021.0550 O2 Positive Flow Cal: dP1 at 44,0 (SP 45 @73,6P	ADC Cnts	LE 1683	1501	✓	
35	0021.0560 O2 Positive Flow Cal: dP1 at 54,2 (SP 55 @72,9P	ADC Cnts	LE 1852	1684	✓	

Test Started On 04/25/24 10:08:53Serial Number TV018021912Elapsed Test Time 43m 23sStatus **PASS**

Page 1 of 2

Audit Info Printed to:doPDF v7 from RESPIRONICS-PC in Troubleshooting: Group Level mode.
File: C:\Program Files\Trilogy Service Cal And Test\Trilogy Repair_PM Cal And Test.exe, Size: 8674304, 05/09/23 10:38
Station Cfg CRC: 5219, 09/01/21 01:39, Test Cfg CRC: 77D6, 09/01/21 01:39, Models Cfg CRC: 2F86, 05/05/23 08:20