

Test Software P/N 4102483Tested Part Number 1040000Test Software Name Trilogy FSA (REPAIR TEST)Software Revision 24.0.0.0Prepared By P. Pascal

Test Report

Step	Description	Units	Limits	Results	Pass	Fail
1	0020.0001 Ambient Air: RH=40,80%; T=23,90Cdeg [15s]	N/A	Pass	TRUE	✓	
2	0020.0010 O2 Sensor Heater On (not attempted for SW ver.1)	N/A	None	None	✓	
3	0020.0010 Press Sensors Cal P1@3,82&49,74cmH2O/9805&33723	20/ADC C	0,00151 to 0,0018	0,00166	✓	
4	0020.0020 Press Sensors Cal P1@3,82&49,74cmH2O/9805&33723	cmH2O	-18,22 to -9,05	-13,70	✓	
5	0020.0030 Press Sensors Cal P1@3,82&49,74cmH2O/9805&33723	ADC Cnts	5994 to 9998	8276	✓	
6	0020.0040 Press Sensors Cal P2@3,82&49,74cmH2O/9805&33723	20/ADC C	0,00114 to 0,0018	0,00143	✓	
7	0020.0050 Press Sensors Cal P2@3,82&49,74cmH2O/9805&33723	cmH2O	-19,53 to 0,00	-5,11	✓	
8	0020.0060 Press Sensors Cal P2@3,82&49,74cmH2O/9805&33723	ADC Cnts	0 to 10399	3574	✓	
9	0020.0950 Press Sensors Cal Pprox@3,82&49,74cmH2O/9805&33	20/ADC C	0,00151 to 0,0018	0,00165	✓	
10	0020.0960 Press Sensors Cal Pprox@3,82&49,74cmH2O/9805&33	cmH2O	-18,22 to -9,05	-13,10	✓	
11	0020.0970 Press Sensors Cal Pprox@3,82&49,74cmH2O/9805&33	ADC Cnts	5994 to 9998	7928	✓	
12	0020.0120 Neg Flow Cal: dP2 at -145,8 (Setpoint 145) [9m	ADC Cnts	GE 101	14613	✓	
13	0020.0130 Neg Flow Cal: dP2 at -133,2 (Setpoint 135) [9m	ADC Cnts	GE 14614	15561	✓	
14	0020.0140 Neg Flow Cal: dP2 at -123,8 (Setpoint 125) [9m	ADC Cnts	GE 15562	16294	✓	
15	0020.0150 Neg Flow Cal: dP2 at -113,0 (Setpoint 115) [9m	ADC Cnts	GE 16295	17135	✓	
16	0020.0160 Neg Flow Cal: dP2 at -103,7 (Setpoint 105) [9m	ADC Cnts	GE 17136	17987	✓	
17	0020.0170 Neg Flow Cal: dP2 at -94,0 (Setpoint 95) [9m 6s	ADC Cnts	GE 17988	18965	✓	
18	0020.0180 Neg Flow Cal: dP2 at -83,3 (Setpoint 85) [9m 6s	ADC Cnts	GE 18966	20051	✓	
19	0020.0190 Neg Flow Cal: dP2 at -72,8 (Setpoint 75) [9m 6s	ADC Cnts	GE 20052	21062	✓	
20	0020.0200 Neg Flow Cal: dP2 at -64,0 (Setpoint 65) [9m 6s	ADC Cnts	GE 21063	22074	✓	
21	0020.0210 Neg Flow Cal: dP2 at -53,2 (Setpoint 55) [9m 6s	ADC Cnts	GE 22075	23318	✓	
22	0020.0220 Neg Flow Cal: dP2 at -43,7 (Setpoint 45) [9m 6s	ADC Cnts	GE 23319	24607	✓	
23	0020.0230 Neg Flow Cal: dP2 at -33,8 (Setpoint 35) [9m 6s	ADC Cnts	GE 24608	25988	✓	
24	0020.0240 Neg Flow Cal: dP2 at -23,0 (Setpoint 25) [9m 6s	ADC Cnts	GE 25989	27620	✓	
25	0020.0250 Neg Flow Cal: dP2 at -14,7 (Setpoint 15) [9m 6s	ADC Cnts	GE 27622	29207	✓	
26	0020.0260 Neg Flow Cal: dP2 at -5,0 (Setpoint 5) [9m 6s]	ADC Cnts	GE 29208	32024	✓	
27	0020.0270 Neg Flow Cal: dP2 at -0,0 (Setpoint 0) [9m 6s]	ADC Cnts	GE 32025	33182	✓	
28	0020.0450 Raw Zero Flow: dP2 at 0,0 (Setpoint 0) [9m 6s]	ADC Cnts	GE 0	33182	✓	
29	0020.0500 Pos Flow Cal: dP2 at 0,0 (Setpoint 5) [15m 36s]	ADC Cnts	LE 37415	33200	✓	
30	0020.0510 Pos Flow Cal: dP2 at 15,0 (Setpoint 15) [15m 36	ADC Cnts	LE 39104	37416	✓	
31	0020.0520 Pos Flow Cal: dP2 at 23,0 (Setpoint 25) [15m 36	ADC Cnts	LE 41143	39105	✓	
32	0020.0530 Pos Flow Cal: dP2 at 38,0 (Setpoint 35) [15m 36	ADC Cnts	LE 42254	41144	✓	
33	0020.0540 Pos Flow Cal: dP2 at 47,0 (Setpoint 45) [15m 36	ADC Cnts	LE 43348	42255	✓	
34	0020.0550 Pos Flow Cal: dP2 at 57,0 (Setpoint 55) [15m 36	ADC Cnts	LE 44488	43349	✓	
35	0020.0560 Pos Flow Cal: dP2 at 67,0 (Setpoint 65) [15m 36	ADC Cnts	LE 45528	44489	✓	

Test Started On 04/08/24 09:37:36Serial Number TV01602190BElapsed Test Time 21m 13sStatus **PASS**

Page 1 of 2

Audit Info Printed to:doPDF v7 from RESPIRONICS-PC in Troubleshooting: Group Level mode.
 File: C:\Program Files\Trilogy Service Cal And Test\Trilogy Repair_PM Cal And Test.exe, Size: 8674304, 05/09/23 10:38
 Station Cfg CRC: 5219, 09/01/21 01:39, Test Cfg CRC: 77D6, 09/01/21 01:39, Models Cfg CRC: 2F86, 05/05/23 08:20