Test Software P/N 4102483

Tested Part Number 1040000



Software Revision 24.0.0.0

Prepared By P. Pascal

Test Report

Test Hepott					
Step	Description	Units	Limits	Results	Pass Fail
36	0021.0570 O2 Positive Flow Cal: dP1 at 64,0 (SP 65 @77,3P	ADC Cnts	LE 1912	1768	<u> </u>
37	0021.0580 O2 Positive Flow Cal: dP1 at 74,3 (SP 75 @76,1P	ADC Cnts	LE 2045	1913	√
38	0021.0590 O2 Positive Flow Cal: dP1 at 84,0 (SP 85 @74,8P	ADC Cnts	LE 2182	2046	√
39	0021.0600 O2 Positive Flow Cal: dP1 at 94,2 (SP 95 @73,5P	ADC Cnts	LE 2304	2183	√
40	0021.0610 O2 Positive Flow Cal: dP1 at 104,0 (SP 105 @72,	ADC Cnts	LE 2420	2306	√
41	0021.0620 O2 Positive Flow Cal: dP1 at 113,8 (SP 115 @70,	ADC Cnts	LE 2537	2421	√
42	0021.0630 O2 Positive Flow Cal: dP1 at 124,8 (SP 125 @68,	ADC Cnts	LE 2631	2538	√
43	0021.0640 O2 Positive Flow Cal: dP1 at 134,3 (SP 135 @67,	ADC Cnts	LE 2726	2632	√
44	0021.0650 O2 Positive Flow Cal: dP1 at 144,8 (SP 145 @65,	ADC Cnts	LE 2986	2727	√
45	0021.0660 O2 Positive Flow Cal: dP1 at 174,5 (SP 175 @62,	ADC Cnts	LE 3112	2986	√
46	0021.0670 O2 Positive Flow Cal: dP1 at 189,5 (SP 190 @59,	ADC Cnts	LE 3999	3113	√
47	0021.0880 02 Sensor Cal (NO_02_ERROR): 485 mV at ambient	N/A	Pass	TRUE	√
48	0021.0930 Write OBM Sensors Cal Table (V: TRUE, A: TRUE)	N/A	Pass	TRUE	√
					+
					+
					++-
					+
		<u> </u>			

Test Started On 06/04/24 01:12:56

Serial Number TV015081808 Elapsed Test Time 16m 30s

Status PASS

Page 2 **of** 2