Test Software P/N 4102483

Tested Part Number 1040000

Test Software Name Trilogy FSA (REPAIR TEST)



Software Revision 24.0.0.0

Prepared By P. Pascal

Test Report

C4	Description	TI==24==	T ::4	D14	Docal E. 11
Step	Description	Units	Limits	Results	Pass Fail
36	0021.0570 O2 Positive Flow Cal: dP1 at 65,0 (SP 65 @77,9P	ADC Cnts	LE 1783	1652	✓
37	0021.0580 O2 Positive Flow Cal: dP1 at 74,3 (SP 75 @77,3P	ADC Cnts	LE 1911	1784	✓
38	0021.0590 O2 Positive Flow Cal: dP1 at 84,8 (SP 85 @76,7P	ADC Cnts	LE 2031	1912	✓
39	0021.0600 O2 Positive Flow Cal: dP1 at 94,8 (SP 95 @76,1P	ADC Cnts	LE 2205	2032	✓
40	0021.0610 O2 Positive Flow Cal: dP1 at 108,3 (SP 105 @75,	ADC Cnts	LE 2265	2206	✓
41	0021.0620 O2 Positive Flow Cal: dP1 at 116,3 (SP 115 @74,	ADC Cnts	LE 2368	2266	✓
42	0021.0630 O2 Positive Flow Cal: dP1 at 125,3 (SP 125 @74,	ADC Cnts	LE 2475	2370	√
43	0021.0640 O2 Positive Flow Cal: dP1 at 136,7 (SP 135 @73,	ADC Cnts	LE 2571	2476	√
44	0021.0650 O2 Positive Flow Cal: dP1 at 146,8 (SP 145 @72,	ADC Cnts	LE 2805	2572	√
45	0021.0660 02 Positive Flow Cal: dP1 at 173,5 (SP 175 @70,	\DC Cnts	LE 2941	2806	√
46	0021.0670 02 Positive Flow Cal: dP1 at 189,8 (SP 190 @69,	ADC Cnts	LE 3999	2942	√
47	0021.0880 02 Sensor Cal (NO_O2_ERROR): 536 mV at ambient	N/A	Pass	TRUE	√
48	0021.0930 Write OBM Sensors Cal Table (V: TRUE, A: TRUE)	N/A	Pass	TRUE	√
					++-
					- - -
					+
					- -
					- -
					+
					+

Test Started On 07/19/24 11:58:47

Serial Number TV019111109 Elapsed Test Time 16m 54s

Status PASS

Page 2 **of** 2