

# Test Report

Step	Description	Units	Limits	Results	Pass	Fail
36	0030.0280 Pos Flow Verify: dP2 at 48,0 (Setpoint 50) [12m	SLPM	42,6 to 53,4	46,6	✓	
37	0030.0290 Pos Flow Verify: dP2 at 37,8 (Setpoint 40) [12m	SLPM	32,8 to 42,8	36,8	✓	
38	0030.0300 Pos Flow Verify: dP2 at 28,0 (Setpoint 30) [12m	SLPM	23,4 to 32,6	27,4	✓	
39	0030.0310 Pos Flow Verify: dP2 at 20,0 (Setpoint 20) [12m	SLPM	15,0 to 25,0	20,1	✓	
40	0030.0320 Pos Flow Verify: dP2 at 10,0 (Setpoint 10) [12m	SLPM	5,5 to 14,5	10,1	✓	
41	0030.0330 Pos Flow Verify: dP2 at 5,0 (Setpoint 5) [12m 5	SLPM	1,2 to 8,8	4,9	✓	
42	0030.0510 Zero Flow Verify: dP2 at 0,0 (Setpoint 0) [12m	SLPM	-2,0 to 2,0	0,1	✓	
43	0030.0550 Neg Flow Verify: dP2 at -138,7 (Setpoint 140) [	SLPM	-147,7 to -129,6	-137,4	✓	
44	0030.0560 Neg Flow Verify: dP2 at -127,5 (Setpoint 130) [	SLPM	-136,1 to -118,9	-125,9	✓	
45	0030.0570 Neg Flow Verify: dP2 at -118,0 (Setpoint 120) [	SLPM	-126,2 to -109,8	-115,7	✓	
46	0030.0580 Neg Flow Verify: dP2 at -107,7 (Setpoint 110) [	SLPM	-115,5 to -99,9	-106,2	✓	
47	0030.0590 Neg Flow Verify: dP2 at -98,8 (Setpoint 100) [1	SLPM	-106,3 to -91,4	-97,1	✓	
48	0030.0600 Neg Flow Verify: dP2 at -88,3 (Setpoint 90) [16	SLPM	-95,4 to -81,3	-86,6	✓	
49	0030.0610 Neg Flow Verify: dP2 at -77,3 (Setpoint 80) [16	SLPM	-83,9 to -70,7	-75,9	✓	
50	0030.0620 Neg Flow Verify: dP2 at -67,9 (Setpoint 70) [16	SLPM	-74,1 to -61,6	-67,1	✓	
51	0030.0630 Neg Flow Verify: dP2 at -58,0 (Setpoint 60) [16	SLPM	-63,8 to -52,2	-57,2	✓	
52	0030.0640 Neg Flow Verify: dP2 at -48,2 (Setpoint 50) [16	SLPM	-53,6 to -42,7	-47,1	✓	
53	0030.0650 Neg Flow Verify: dP2 at -38,0 (Setpoint 40) [16	SLPM	-43,0 to -33,0	-36,8	✓	
54	0030.0660 Neg Flow Verify: dP2 at -28,0 (Setpoint 30) [16	SLPM	-32,6 to -23,4	-27,5	✓	
55	0030.0670 Neg Flow Verify: dP2 at -18,3 (Setpoint 20) [16	SLPM	-23,3 to -13,3	-17,8	✓	
56	0030.0680 Neg Flow Verify: dP2 at -10,0 (Setpoint 10) [16	SLPM	-14,5 to -5,5	-9,0	✓	
57	0030.0690 Neg Flow Verify: dP2 at -5,0 (Setpoint 5) [16m	SLPM	-8,8 to -1,2	-4,2	✓	
58	0030.0700 Neg Flow Verify: dP2 at -0,0 (Setpoint 0) [16m	SLPM	-2,0 to 2,0	0,1	✓	
59	0030.0950 Contr.Press.Ver.(8973): P1 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,03	✓	
60	0030.0960 Monit.Press.Ver.(3467): P2 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,00	✓	
61	0030.0160 Pprox Press. Ver.(8939): P2 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,05	✓	
62	0030.0970 Contr.Press.Ver.(11355): P1 at 3,92 (SP 4, 1, 1)	cmH2O	2,92 to 4,92	3,99	✓	
63	0030.0980 Monit.Press.Ver.(6168): P2 at 3,92 (SP 4, 1, 1)	cmH2O	2,92 to 4,92	3,86	✓	
64	0030.0161 Pprox Press. Ver.(11313): P2 at 3,92 (SP 4, 1,	cmH2O	2,92 to 4,92	4,00	✓	
65	0030.0990 Contr.Press.Ver.(19768): P1 at 17,89 (SP 18, 1,	cmH2O	16,89 to 18,89	18,00	✓	
66	0030.1000 Monit.Press.Ver.(15871): P2 at 17,89 (SP 18, 1,	cmH2O	16,89 to 18,89	17,83	✓	
67	0030.0162 Pprox Press. Ver.(19678): P2 at 17,89 (SP 18, 1	cmH2O	16,89 to 18,89	17,95	✓	
68	0030.1010 Contr.Press.Ver.(28184): P1 at 31,89 (SP 32, 1,	cmH2O	30,89 to 32,89	32,00	✓	
69	0030.1020 Monit.Press.Ver.(25612): P2 at 31,89 (SP 32, 1,	cmH2O	30,89 to 32,89	31,88	✓	
70	0030.0163 Pprox Press. Ver.(28096): P2 at 31,89 (SP 32, 1	cmH2O	30,89 to 32,89	31,95	✓	

Test Started On 07/24/24 03:34:01Serial Number TV115081216Elapsed Test Time 53m 12sStatus **PASS**

Page 2 of 6

Audit Info Printed to:doPDF v7 from RESPIRONICS-PC in Production mode.  
 File: C:\Program Files\Trilogy Service Cal And Test\Trilogy Repair\_PM Cal And Test.exe, Size: 8674304, 05/09/23 10:38  
 Station Cfg CRC: 5219, 09/01/21 01:39, Test Cfg CRC: 94CF, 09/01/21 01:39, Models Cfg CRC: 2F86, 05/05/23 08:20